

DWT6 10'-13000 COMPARTMENT
51,062 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	18	24.5	1,721	48.5	4,833	72.5	8,856	96.5	13,517
1.0	29	25.0	1,774	49.0	4,909	73.0	8,947	97.0	13,619
1.5	43	25.5	1,827	49.5	4,985	73.5	9,039	97.5	13,721
2.0	58	26.0	1,882	50.0	5,061	74.0	9,131	98.0	13,824
2.5	74	26.5	1,936	50.5	5,138	74.5	9,223	98.5	13,927
3.0	92	27.0	1,992	51.0	5,215	75.0	9,316	99.0	14,030
3.5	111	27.5	2,048	51.5	5,293	75.5	9,409	99.5	14,133
4.0	132	28.0	2,104	52.0	5,371	76.0	9,502	100.0	14,236
4.5	153	28.5	2,161	52.5	5,449	76.5	9,595	100.5	14,340
5.0	176	29.0	2,219	53.0	5,528	77.0	9,688	101.0	14,443
5.5	200	29.5	2,277	53.5	5,607	77.5	9,782	101.5	14,547
6.0	225	30.0	2,335	54.0	5,686	78.0	9,876	102.0	14,651
6.5	251	30.5	2,394	54.5	5,766	78.5	9,970	102.5	14,756
7.0	278	31.0	2,454	55.0	5,846	79.0	10,065	103.0	14,860
7.5	306	31.5	2,514	55.5	5,926	79.5	10,160	103.5	14,964
8.0	335	32.0	2,574	56.0	6,007	80.0	10,255	104.0	15,069
8.5	365	32.5	2,636	56.5	6,088	80.5	10,350	104.5	15,174
9.0	395	33.0	2,697	57.0	6,170	81.0	10,446	105.0	15,279
9.5	427	33.5	2,759	57.5	6,252	81.5	10,541	105.5	15,384
10.0	460	34.0	2,822	58.0	6,334	82.0	10,637	106.0	15,489
10.5	493	34.5	2,885	58.5	6,416	82.5	10,734	106.5	15,595
11.0	527	35.0	2,948	59.0	6,499	83.0	10,830	107.0	15,700
11.5	562	35.5	3,012	59.5	6,583	83.5	10,927	107.5	15,806
12.0	598	36.0	3,077	60.0	6,666	84.0	11,024	108.0	15,912
12.5	634	36.5	3,142	60.5	6,750	84.5	11,121	108.5	16,018
13.0	672	37.0	3,207	61.0	6,834	85.0	11,218	109.0	16,124
13.5	710	37.5	3,273	61.5	6,919	85.5	11,316	109.5	16,230
14.0	749	38.0	3,340	62.0	7,004	86.0	11,414	110.0	16,337
14.5	788	38.5	3,406	62.5	7,089	86.5	11,512	110.5	16,443
15.0	829	39.0	3,474	63.0	7,174	87.0	11,610	111.0	16,550
15.5	870	39.5	3,541	63.5	7,260	87.5	11,708	111.5	16,657
16.0	911	40.0	3,610	64.0	7,346	88.0	11,807	112.0	16,764
16.5	954	40.5	3,678	64.5	7,433	88.5	11,906	112.5	16,871
17.0	997	41.0	3,747	65.0	7,519	89.0	12,005	113.0	16,978
17.5	1,041	41.5	3,817	65.5	7,606	89.5	12,105	113.5	17,085
18.0	1,085	42.0	3,887	66.0	7,694	90.0	12,204	114.0	17,193
18.5	1,130	42.5	3,957	66.5	7,781	90.5	12,304	114.5	17,300
19.0	1,176	43.0	4,028	67.0	7,869	91.0	12,404	115.0	17,408
19.5	1,222	43.5	4,099	67.5	7,958	91.5	12,504	115.5	17,516
20.0	1,270	44.0	4,170	68.0	8,046	92.0	12,604	116.0	17,624
20.5	1,317	44.5	4,243	68.5	8,135	92.5	12,705	116.5	17,732
21.0	1,366	45.0	4,315	69.0	8,224	93.0	12,806	117.0	17,840
21.5	1,414	45.5	4,388	69.5	8,314	93.5	12,907	117.5	17,948
22.0	1,464	46.0	4,461	70.0	8,403	94.0	13,008	118.0	18,057
22.5	1,514	46.5	4,535	70.5	8,493	94.5	13,109	118.5	18,165
23.0	1,565	47.0	4,609	71.0	8,584	95.0	13,211	119.0	18,274
23.5	1,616	47.5	4,683	71.5	8,674	95.5	13,313	119.5	18,383
24.0	1,668	48.0	4,758	72.0	8,765	96.0	13,414	120.0	18,491

DWT6 10'-13000 COMPARTMENT
51,062 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	18,600	144.5	23,917	168.5	29,287	192.5	34,533
121.0	18,709	145.0	24,029	169.0	29,398	193.0	34,639
121.5	18,818	145.5	24,141	169.5	29,509	193.5	34,746
122.0	18,928	146.0	24,253	170.0	29,620	194.0	34,852
122.5	19,037	146.5	24,365	170.5	29,731	194.5	34,959
123.0	19,146	147.0	24,477	171.0	29,842	195.0	35,065
123.5	19,256	147.5	24,589	171.5	29,953	195.5	35,171
124.0	19,366	148.0	24,701	172.0	30,064	196.0	35,277
124.5	19,475	148.5	24,813	172.5	30,175	196.5	35,382
125.0	19,585	149.0	24,925	173.0	30,286	197.0	35,488
125.5	19,695	149.5	25,037	173.5	30,396	197.5	35,593
126.0	19,805	150.0	25,149	174.0	30,507	198.0	35,698
126.5	19,915	150.5	25,262	174.5	30,617	198.5	35,804
127.0	20,025	151.0	25,374	175.0	30,728	199.0	35,908
127.5	20,135	151.5	25,486	175.5	30,838	199.5	36,013
128.0	20,245	152.0	25,598	176.0	30,948	200.0	36,118
128.5	20,356	152.5	25,710	176.5	31,058	200.5	36,222
129.0	20,466	153.0	25,822	177.0	31,168	201.0	36,327
129.5	20,577	153.5	25,934	177.5	31,278	201.5	36,431
130.0	20,687	154.0	26,046	178.0	31,388	202.0	36,535
130.5	20,798	154.5	26,158	178.5	31,498	202.5	36,639
131.0	20,908	155.0	26,270	179.0	31,608	203.0	36,742
131.5	21,019	155.5	26,382	179.5	31,718	203.5	36,846
132.0	21,130	156.0	26,494	180.0	31,827	204.0	36,949
132.5	21,241	156.5	26,607	180.5	31,937	204.5	37,052
133.0	21,352	157.0	26,719	181.0	32,046	205.0	37,155
133.5	21,463	157.5	26,831	181.5	32,155	205.5	37,258
134.0	21,574	158.0	26,943	182.0	32,265	206.0	37,361
134.5	21,685	158.5	27,054	182.5	32,374	206.5	37,463
135.0	21,796	159.0	27,166	183.0	32,483	207.0	37,565
135.5	21,908	159.5	27,278	183.5	32,592	207.5	37,667
136.0	22,019	160.0	27,390	184.0	32,700	208.0	37,769
136.5	22,130	160.5	27,502	184.5	32,809	208.5	37,871
137.0	22,242	161.0	27,614	185.0	32,918	209.0	37,972
137.5	22,353	161.5	27,726	185.5	33,026	209.5	38,074
138.0	22,464	162.0	27,838	186.0	33,135	210.0	38,175
138.5	22,576	162.5	27,949	186.5	33,243	210.5	38,276
139.0	22,688	163.0	28,061	187.0	33,351	211.0	38,377
139.5	22,799	163.5	28,173	187.5	33,459	211.5	38,477
140.0	22,911	164.0	28,284	188.0	33,567	212.0	38,577
140.5	23,023	164.5	28,396	188.5	33,675	212.5	38,678
141.0	23,134	165.0	28,507	189.0	33,782	213.0	38,778
141.5	23,246	165.5	28,619	189.5	33,890	213.5	38,877
142.0	23,358	166.0	28,730	190.0	33,997	214.0	38,977
142.5	23,470	166.5	28,842	190.5	34,105	214.5	39,076
143.0	23,581	167.0	28,953	191.0	34,212	215.0	39,175
143.5	23,693	167.5	29,065	191.5	34,319	215.5	39,274
144.0	23,805	168.0	29,176	192.0	34,426	216.0	39,373

DWT6 10'-13000 COMPARTMENT
51,062 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	39,471	240.5	43,905	264.5	47,602	288.5	50,243
217.0	39,569	241.0	43,990	265.0	47,669	289.0	50,283
217.5	39,667	241.5	44,075	265.5	47,736	289.5	50,322
218.0	39,765	242.0	44,160	266.0	47,802	290.0	50,361
218.5	39,863	242.5	44,245	266.5	47,868	290.5	50,399
219.0	39,960	243.0	44,329	267.0	47,933	291.0	50,436
219.5	40,057	243.5	44,412	267.5	47,998	291.5	50,472
220.0	40,154	244.0	44,496	268.0	48,063	292.0	50,508
220.5	40,251	244.5	44,579	268.5	48,127	292.5	50,543
221.0	40,347	245.0	44,662	269.0	48,190	293.0	50,577
221.5	40,443	245.5	44,744	269.5	48,253	293.5	50,610
222.0	40,539	246.0	44,827	270.0	48,316	294.0	50,643
222.5	40,635	246.5	44,908	270.5	48,378	294.5	50,674
223.0	40,731	247.0	44,990	271.0	48,439	295.0	50,705
223.5	40,826	247.5	45,071	271.5	48,500	295.5	50,734
224.0	40,921	248.0	45,152	272.0	48,561	296.0	50,763
224.5	41,016	248.5	45,232	272.5	48,621	296.5	50,791
225.0	41,110	249.0	45,312	273.0	48,680	297.0	50,818
225.5	41,204	249.5	45,392	273.5	48,739	297.5	50,843
226.0	41,298	250.0	45,471	274.0	48,798	298.0	50,868
226.5	41,392	250.5	45,550	274.5	48,856	298.5	50,892
227.0	41,486	251.0	45,629	275.0	48,913	299.0	50,915
227.5	41,579	251.5	45,707	275.5	48,970	299.5	50,936
228.0	41,672	252.0	45,785	276.0	49,026	300.0	50,956
228.5	41,764	252.5	45,862	276.5	49,082	300.5	50,975
229.0	41,857	253.0	45,939	277.0	49,137	301.0	50,993
229.5	41,949	253.5	46,016	277.5	49,192	301.5	51,009
230.0	42,041	254.0	46,092	278.0	49,246	302.0	51,024
230.5	42,133	254.5	46,168	278.5	49,299	302.5	51,037
231.0	42,224	255.0	46,244	279.0	49,352	303.0	51,048
231.5	42,315	255.5	46,319	279.5	49,405	303.5	51,056
232.0	42,406	256.0	46,394	280.0	49,457	304.0	51,062
232.5	42,496	256.5	46,468	280.5	49,508		
233.0	42,586	257.0	46,542	281.0	49,559		
233.5	42,676	257.5	46,616	281.5	49,609		
234.0	42,766	258.0	46,689	282.0	49,658		
234.5	42,855	258.5	46,762	282.5	49,707		
235.0	42,945	259.0	46,834	283.0	49,755		
235.5	43,033	259.5	46,906	283.5	49,803		
236.0	43,122	260.0	46,978	284.0	49,850		
236.5	43,210	260.5	47,049	284.5	49,896		
237.0	43,298	261.0	47,119	285.0	49,942		
237.5	43,386	261.5	47,190	285.5	49,987		
238.0	43,473	262.0	47,259	286.0	50,031		
238.5	43,560	262.5	47,329	286.5	50,075		
239.0	43,647	263.0	47,398	287.0	50,118		
239.5	43,733	263.5	47,466	287.5	50,160		
240.0	43,819	264.0	47,534	288.0	50,202		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.