

**DWT6 10'-2000 COMPARTMENT**  
**75,522 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	30	24.5	2,687	48.5	7,397	72.5	13,379	96.5	20,235
1.0	48	25.0	2,769	49.0	7,510	73.0	13,514	97.0	20,385
1.5	70	25.5	2,851	49.5	7,624	73.5	13,649	97.5	20,536
2.0	94	26.0	2,934	50.0	7,738	74.0	13,785	98.0	20,686
2.5	121	26.5	3,018	50.5	7,853	74.5	13,921	98.5	20,837
3.0	150	27.0	3,102	51.0	7,968	75.0	14,058	99.0	20,987
3.5	180	27.5	3,188	51.5	8,084	75.5	14,195	99.5	21,139
4.0	213	28.0	3,274	52.0	8,201	76.0	14,332	100.0	21,290
4.5	248	28.5	3,361	52.5	8,318	76.5	14,469	100.5	21,441
5.0	284	29.0	3,449	53.0	8,435	77.0	14,607	101.0	21,593
5.5	322	29.5	3,537	53.5	8,553	77.5	14,746	101.5	21,745
6.0	362	30.0	3,626	54.0	8,672	78.0	14,884	102.0	21,898
6.5	404	30.5	3,716	54.5	8,791	78.5	15,024	102.5	22,050
7.0	446	31.0	3,807	55.0	8,910	79.0	15,163	103.0	22,203
7.5	491	31.5	3,898	55.5	9,030	79.5	15,303	103.5	22,356
8.0	536	32.0	3,990	56.0	9,151	80.0	15,443	104.0	22,509
8.5	584	32.5	4,083	56.5	9,272	80.5	15,583	104.5	22,662
9.0	632	33.0	4,177	57.0	9,393	81.0	15,724	105.0	22,816
9.5	682	33.5	4,271	57.5	9,515	81.5	15,865	105.5	22,969
10.0	733	34.0	4,366	58.0	9,638	82.0	16,006	106.0	23,123
10.5	786	34.5	4,462	58.5	9,761	82.5	16,148	106.5	23,278
11.0	839	35.0	4,558	59.0	9,884	83.0	16,290	107.0	23,432
11.5	894	35.5	4,655	59.5	10,008	83.5	16,432	107.5	23,586
12.0	950	36.0	4,753	60.0	10,132	84.0	16,575	108.0	23,741
12.5	1,007	36.5	4,851	60.5	10,257	84.5	16,718	108.5	23,896
13.0	1,066	37.0	4,950	61.0	10,382	85.0	16,861	109.0	24,051
13.5	1,125	37.5	5,049	61.5	10,508	85.5	17,005	109.5	24,207
14.0	1,186	38.0	5,150	62.0	10,634	86.0	17,148	110.0	24,362
14.5	1,248	38.5	5,251	62.5	10,760	86.5	17,293	110.5	24,518
15.0	1,310	39.0	5,352	63.0	10,887	87.0	17,437	111.0	24,674
15.5	1,374	39.5	5,454	63.5	11,015	87.5	17,582	111.5	24,830
16.0	1,439	40.0	5,557	64.0	11,142	88.0	17,727	112.0	24,986
16.5	1,505	40.5	5,661	64.5	11,271	88.5	17,872	112.5	25,142
17.0	1,572	41.0	5,765	65.0	11,399	89.0	18,018	113.0	25,299
17.5	1,640	41.5	5,870	65.5	11,528	89.5	18,164	113.5	25,456
18.0	1,708	42.0	5,975	66.0	11,658	90.0	18,310	114.0	25,613
18.5	1,778	42.5	6,081	66.5	11,788	90.5	18,457	114.5	25,770
19.0	1,849	43.0	6,187	67.0	11,918	91.0	18,603	115.0	25,927
19.5	1,921	43.5	6,294	67.5	12,049	91.5	18,750	115.5	26,084
20.0	1,994	44.0	6,402	68.0	12,180	92.0	18,898	116.0	26,242
20.5	2,067	44.5	6,510	68.5	12,312	92.5	19,045	116.5	26,400
21.0	2,142	45.0	6,619	69.0	12,444	93.0	19,193	117.0	26,557
21.5	2,217	45.5	6,728	69.5	12,576	93.5	19,341	117.5	26,715
22.0	2,293	46.0	6,838	70.0	12,709	94.0	19,490	118.0	26,874
22.5	2,370	46.5	6,949	70.5	12,842	94.5	19,638	118.5	27,032
23.0	2,448	47.0	7,060	71.0	12,976	95.0	19,787	119.0	27,190
23.5	2,527	47.5	7,172	71.5	13,110	95.5	19,936	119.5	27,349
24.0	2,607	48.0	7,284	72.0	13,244	96.0	20,086	120.0	27,508

**DWT6 10'-20000 COMPARTMENT**  
**75,522 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	27,667	144.5	35,412	168.5	43,229	192.5	50,879
121.0	27,826	145.0	35,575	169.0	43,391	193.0	51,035
121.5	27,985	145.5	35,738	169.5	43,553	193.5	51,190
122.0	28,144	146.0	35,901	170.0	43,715	194.0	51,346
122.5	28,304	146.5	36,064	170.5	43,876	194.5	51,501
123.0	28,463	147.0	36,227	171.0	44,038	195.0	51,656
123.5	28,623	147.5	36,390	171.5	44,199	195.5	51,811
124.0	28,783	148.0	36,553	172.0	44,361	196.0	51,966
124.5	28,942	148.5	36,716	172.5	44,522	196.5	52,120
125.0	29,102	149.0	36,879	173.0	44,683	197.0	52,275
125.5	29,263	149.5	37,043	173.5	44,845	197.5	52,429
126.0	29,423	150.0	37,206	174.0	45,006	198.0	52,583
126.5	29,583	150.5	37,369	174.5	45,167	198.5	52,736
127.0	29,744	151.0	37,532	175.0	45,327	199.0	52,890
127.5	29,904	151.5	37,695	175.5	45,488	199.5	53,043
128.0	30,065	152.0	37,858	176.0	45,649	200.0	53,196
128.5	30,226	152.5	38,022	176.5	45,809	200.5	53,349
129.0	30,387	153.0	38,185	177.0	45,970	201.0	53,502
129.5	30,548	153.5	38,348	177.5	46,130	201.5	53,654
130.0	30,709	154.0	38,511	178.0	46,290	202.0	53,806
130.5	30,870	154.5	38,674	178.5	46,451	202.5	53,958
131.0	31,031	155.0	38,837	179.0	46,611	203.0	54,110
131.5	31,193	155.5	39,000	179.5	46,771	203.5	54,262
132.0	31,354	156.0	39,163	180.0	46,930	204.0	54,413
132.5	31,515	156.5	39,326	180.5	47,090	204.5	54,564
133.0	31,677	157.0	39,490	181.0	47,249	205.0	54,715
133.5	31,839	157.5	39,653	181.5	47,409	205.5	54,865
134.0	32,001	158.0	39,816	182.0	47,568	206.0	55,016
134.5	32,162	158.5	39,979	182.5	47,727	206.5	55,166
135.0	32,324	159.0	40,141	183.0	47,886	207.0	55,316
135.5	32,486	159.5	40,304	183.5	48,045	207.5	55,465
136.0	32,648	160.0	40,467	184.0	48,204	208.0	55,615
136.5	32,811	160.5	40,630	184.5	48,362	208.5	55,764
137.0	32,973	161.0	40,793	185.0	48,521	209.0	55,913
137.5	33,135	161.5	40,956	185.5	48,679	209.5	56,061
138.0	33,297	162.0	41,118	186.0	48,837	210.0	56,210
138.5	33,460	162.5	41,281	186.5	48,995	210.5	56,358
139.0	33,622	163.0	41,444	187.0	49,153	211.0	56,506
139.5	33,785	163.5	41,606	187.5	49,311	211.5	56,653
140.0	33,947	164.0	41,769	188.0	49,468	212.0	56,800
140.5	34,110	164.5	41,931	188.5	49,626	212.5	56,947
141.0	34,272	165.0	42,094	189.0	49,783	213.0	57,094
141.5	34,435	165.5	42,256	189.5	49,940	213.5	57,241
142.0	34,598	166.0	42,418	190.0	50,097	214.0	57,387
142.5	34,761	166.5	42,581	190.5	50,254	214.5	57,533
143.0	34,923	167.0	42,743	191.0	50,410	215.0	57,678
143.5	35,086	167.5	42,905	191.5	50,566	215.5	57,824
144.0	35,249	168.0	43,067	192.0	50,723	216.0	57,969

**DWT6 10'-20000 COMPARTMENT**  
**75,522 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	58,113	240.5	64,660	264.5	70,191	288.5	74,226
217.0	58,258	241.0	64,787	265.0	70,292	289.0	74,288
217.5	58,402	241.5	64,914	265.5	70,393	289.5	74,350
218.0	58,546	242.0	65,040	266.0	70,493	290.0	74,410
218.5	58,689	242.5	65,165	266.5	70,593	290.5	74,470
219.0	58,832	243.0	65,290	267.0	70,691	291.0	74,528
219.5	58,975	243.5	65,415	267.5	70,790	291.5	74,585
220.0	59,118	244.0	65,539	268.0	70,887	292.0	74,641
220.5	59,260	244.5	65,663	268.5	70,984	292.5	74,695
221.0	59,402	245.0	65,786	269.0	71,080	293.0	74,749
221.5	59,544	245.5	65,909	269.5	71,176	293.5	74,801
222.0	59,685	246.0	66,031	270.0	71,271	294.0	74,852
222.5	59,826	246.5	66,153	270.5	71,365	294.5	74,902
223.0	59,967	247.0	66,274	271.0	71,458	295.0	74,950
223.5	60,107	247.5	66,395	271.5	71,551	295.5	74,997
224.0	60,247	248.0	66,516	272.0	71,643	296.0	75,042
224.5	60,387	248.5	66,636	272.5	71,734	296.5	75,086
225.0	60,526	249.0	66,755	273.0	71,825	297.0	75,129
225.5	60,665	249.5	66,874	273.5	71,914	297.5	75,170
226.0	60,803	250.0	66,992	274.0	72,004	298.0	75,209
226.5	60,942	250.5	67,110	274.5	72,092	298.5	75,247
227.0	61,080	251.0	67,228	275.0	72,179	299.0	75,283
227.5	61,217	251.5	67,345	275.5	72,266	299.5	75,318
228.0	61,354	252.0	67,461	276.0	72,352	300.0	75,350
228.5	61,491	252.5	67,577	276.5	72,437	300.5	75,381
229.0	61,628	253.0	67,692	277.0	72,522	301.0	75,409
229.5	61,764	253.5	67,807	277.5	72,606	301.5	75,435
230.0	61,900	254.0	67,921	278.0	72,688	302.0	75,459
230.5	62,035	254.5	68,035	278.5	72,771	302.5	75,480
231.0	62,170	255.0	68,148	279.0	72,852	303.0	75,498
231.5	62,305	255.5	68,261	279.5	72,932	303.5	75,513
232.0	62,439	256.0	68,373	280.0	73,012	304.0	75,522
232.5	62,573	256.5	68,485	280.5	73,090		
233.0	62,706	257.0	68,596	281.0	73,168		
233.5	62,839	257.5	68,706	281.5	73,245		
234.0	62,972	258.0	68,816	282.0	73,321		
234.5	63,104	258.5	68,925	282.5	73,397		
235.0	63,236	259.0	69,034	283.0	73,471		
235.5	63,368	259.5	69,142	283.5	73,544		
236.0	63,499	260.0	69,250	284.0	73,617		
236.5	63,630	260.5	69,357	284.5	73,688		
237.0	63,760	261.0	69,463	285.0	73,759		
237.5	63,890	261.5	69,569	285.5	73,829		
238.0	64,019	262.0	69,674	286.0	73,897		
238.5	64,148	262.5	69,778	286.5	73,965		
239.0	64,277	263.0	69,882	287.0	74,032		
239.5	64,405	263.5	69,986	287.5	74,098		
240.0	64,533	264.0	70,089	288.0	74,162		

# Fiber Glass Systems



## HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

## Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste      Description - PASTE02 - for Salt and Chloride Solutions  
7915 East Elm Street  
Houston, TX 77012  
Phone (713) 926-4780  
E-Mail Sales@KolorKut.com

## Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

## NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West  
Conroe, TX 77303  
Tel: 936-756-7731  
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.