

DWT6 10'-25000 COMPARTMENT
94,522 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	39	24.5	3,438	48.5	9,388	72.5	16,891	96.5	25,454
1.0	63	25.0	3,542	49.0	9,530	73.0	17,060	97.0	25,641
1.5	91	25.5	3,646	49.5	9,673	73.5	17,230	97.5	25,829
2.0	122	26.0	3,751	50.0	9,817	74.0	17,400	98.0	26,016
2.5	157	26.5	3,858	50.5	9,962	74.5	17,570	98.5	26,204
3.0	194	27.0	3,965	51.0	10,107	75.0	17,741	99.0	26,392
3.5	234	27.5	4,073	51.5	10,253	75.5	17,912	99.5	26,580
4.0	277	28.0	4,183	52.0	10,399	76.0	18,084	100.0	26,769
4.5	321	28.5	4,293	52.5	10,546	76.5	18,256	100.5	26,958
5.0	368	29.0	4,404	53.0	10,694	77.0	18,429	101.0	27,147
5.5	418	29.5	4,516	53.5	10,842	77.5	18,601	101.5	27,336
6.0	469	30.0	4,629	54.0	10,991	78.0	18,775	102.0	27,526
6.5	522	30.5	4,743	54.5	11,141	78.5	18,949	102.5	27,716
7.0	577	31.0	4,858	55.0	11,291	79.0	19,123	103.0	27,906
7.5	634	31.5	4,974	55.5	11,442	79.5	19,297	103.5	28,097
8.0	693	32.0	5,090	56.0	11,593	80.0	19,472	104.0	28,288
8.5	754	32.5	5,208	56.5	11,745	80.5	19,648	104.5	28,479
9.0	816	33.0	5,326	57.0	11,897	81.0	19,824	105.0	28,670
9.5	880	33.5	5,445	57.5	12,050	81.5	20,000	105.5	28,862
10.0	946	34.0	5,565	58.0	12,204	82.0	20,176	106.0	29,053
10.5	1,013	34.5	5,686	58.5	12,358	82.5	20,353	106.5	29,245
11.0	1,082	35.0	5,808	59.0	12,513	83.0	20,531	107.0	29,438
11.5	1,152	35.5	5,931	59.5	12,668	83.5	20,709	107.5	29,630
12.0	1,224	36.0	6,054	60.0	12,824	84.0	20,887	108.0	29,823
12.5	1,297	36.5	6,178	60.5	12,981	84.5	21,065	108.5	30,016
13.0	1,372	37.0	6,303	61.0	13,138	85.0	21,244	109.0	30,209
13.5	1,448	37.5	6,429	61.5	13,295	85.5	21,423	109.5	30,402
14.0	1,525	38.0	6,556	62.0	13,453	86.0	21,603	110.0	30,596
14.5	1,604	38.5	6,683	62.5	13,612	86.5	21,783	110.5	30,790
15.0	1,684	39.0	6,811	63.0	13,771	87.0	21,963	111.0	30,984
15.5	1,766	39.5	6,940	63.5	13,931	87.5	22,144	111.5	31,178
16.0	1,849	40.0	7,070	64.0	14,091	88.0	22,325	112.0	31,373
16.5	1,933	40.5	7,201	64.5	14,252	88.5	22,507	112.5	31,567
17.0	2,018	41.0	7,332	65.0	14,413	89.0	22,688	113.0	31,762
17.5	2,105	41.5	7,464	65.5	14,575	89.5	22,870	113.5	31,957
18.0	2,193	42.0	7,597	66.0	14,737	90.0	23,053	114.0	32,153
18.5	2,282	42.5	7,730	66.5	14,900	90.5	23,236	114.5	32,348
19.0	2,372	43.0	7,865	67.0	15,063	91.0	23,419	115.0	32,544
19.5	2,463	43.5	8,000	67.5	15,227	91.5	23,602	115.5	32,740
20.0	2,556	44.0	8,135	68.0	15,391	92.0	23,786	116.0	32,936
20.5	2,650	44.5	8,272	68.5	15,556	92.5	23,970	116.5	33,132
21.0	2,744	45.0	8,409	69.0	15,721	93.0	24,155	117.0	33,329
21.5	2,840	45.5	8,546	69.5	15,887	93.5	24,339	117.5	33,525
22.0	2,937	46.0	8,685	70.0	16,053	94.0	24,524	118.0	33,722
22.5	3,035	46.5	8,824	70.5	16,220	94.5	24,710	118.5	33,919
23.0	3,135	47.0	8,964	71.0	16,387	95.0	24,896	119.0	34,116
23.5	3,235	47.5	9,105	71.5	16,555	95.5	25,082	119.5	34,314
24.0	3,336	48.0	9,246	72.0	16,723	96.0	25,268	120.0	34,511

DWT6 10'-25000 COMPARTMENT
94,522 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	34,709	144.5	44,341	168.5	54,059	192.5	63,576
121.0	34,907	145.0	44,544	169.0	54,260	193.0	63,770
121.5	35,105	145.5	44,746	169.5	54,461	193.5	63,963
122.0	35,303	146.0	44,949	170.0	54,662	194.0	64,157
122.5	35,501	146.5	45,151	170.5	54,863	194.5	64,350
123.0	35,700	147.0	45,354	171.0	55,064	195.0	64,544
123.5	35,899	147.5	45,557	171.5	55,265	195.5	64,736
124.0	36,097	148.0	45,760	172.0	55,466	196.0	64,929
124.5	36,296	148.5	45,962	172.5	55,667	196.5	65,122
125.0	36,495	149.0	46,165	173.0	55,867	197.0	65,314
125.5	36,694	149.5	46,368	173.5	56,068	197.5	65,506
126.0	36,894	150.0	46,571	174.0	56,268	198.0	65,698
126.5	37,093	150.5	46,773	174.5	56,468	198.5	65,889
127.0	37,293	151.0	46,976	175.0	56,668	199.0	66,080
127.5	37,493	151.5	47,179	175.5	56,868	199.5	66,271
128.0	37,692	152.0	47,382	176.0	57,068	200.0	66,462
128.5	37,892	152.5	47,585	176.5	57,268	200.5	66,652
129.0	38,093	153.0	47,788	177.0	57,467	201.0	66,843
129.5	38,293	153.5	47,990	177.5	57,667	201.5	67,033
130.0	38,493	154.0	48,193	178.0	57,866	202.0	67,222
130.5	38,694	154.5	48,396	178.5	58,065	202.5	67,412
131.0	38,894	155.0	48,599	179.0	58,264	203.0	67,601
131.5	39,095	155.5	48,801	179.5	58,463	203.5	67,790
132.0	39,295	156.0	49,004	180.0	58,662	204.0	67,978
132.5	39,496	156.5	49,207	180.5	58,860	204.5	68,167
133.0	39,697	157.0	49,410	181.0	59,059	205.0	68,355
133.5	39,898	157.5	49,612	181.5	59,257	205.5	68,542
134.0	40,100	158.0	49,815	182.0	59,455	206.0	68,730
134.5	40,301	158.5	50,017	182.5	59,653	206.5	68,917
135.0	40,502	159.0	50,220	183.0	59,851	207.0	69,104
135.5	40,704	159.5	50,423	183.5	60,049	207.5	69,290
136.0	40,905	160.0	50,625	184.0	60,246	208.0	69,477
136.5	41,107	160.5	50,827	184.5	60,444	208.5	69,663
137.0	41,308	161.0	51,030	185.0	60,641	209.0	69,848
137.5	41,510	161.5	51,232	185.5	60,838	209.5	70,033
138.0	41,712	162.0	51,435	186.0	61,034	210.0	70,218
138.5	41,914	162.5	51,637	186.5	61,231	210.5	70,403
139.0	42,116	163.0	51,839	187.0	61,428	211.0	70,588
139.5	42,318	163.5	52,041	187.5	61,624	211.5	70,772
140.0	42,520	164.0	52,243	188.0	61,820	212.0	70,955
140.5	42,722	164.5	52,445	188.5	62,016	212.5	71,139
141.0	42,924	165.0	52,647	189.0	62,211	213.0	71,322
141.5	43,126	165.5	52,849	189.5	62,407	213.5	71,505
142.0	43,329	166.0	53,051	190.0	62,602	214.0	71,687
142.5	43,531	166.5	53,253	190.5	62,797	214.5	71,869
143.0	43,733	167.0	53,454	191.0	62,992	215.0	72,051
143.5	43,936	167.5	53,656	191.5	63,187	215.5	72,232
144.0	44,138	168.0	53,857	192.0	63,381	216.0	72,413

DWT6 10'-25000 COMPARTMENT
94,522 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	72,594	240.5	80,782	264.5	87,737	288.5	92,855
217.0	72,774	241.0	80,941	265.0	87,865	289.0	92,935
217.5	72,954	241.5	81,100	265.5	87,992	289.5	93,014
218.0	73,133	242.0	81,258	266.0	88,118	290.0	93,091
218.5	73,313	242.5	81,415	266.5	88,244	290.5	93,167
219.0	73,492	243.0	81,572	267.0	88,369	291.0	93,241
219.5	73,670	243.5	81,729	267.5	88,493	291.5	93,314
220.0	73,848	244.0	81,884	268.0	88,616	292.0	93,386
220.5	74,026	244.5	82,040	268.5	88,739	292.5	93,456
221.0	74,203	245.0	82,194	269.0	88,860	293.0	93,525
221.5	74,380	245.5	82,348	269.5	88,981	293.5	93,591
222.0	74,557	246.0	82,502	270.0	89,101	294.0	93,657
222.5	74,733	246.5	82,655	270.5	89,220	294.5	93,721
223.0	74,908	247.0	82,807	271.0	89,338	295.0	93,783
223.5	75,084	247.5	82,959	271.5	89,456	295.5	93,843
224.0	75,259	248.0	83,110	272.0	89,572	296.0	93,901
224.5	75,433	248.5	83,261	272.5	89,688	296.5	93,958
225.0	75,607	249.0	83,411	273.0	89,802	297.0	94,013
225.5	75,781	249.5	83,560	273.5	89,916	297.5	94,066
226.0	75,954	250.0	83,709	274.0	90,029	298.0	94,117
226.5	76,127	250.5	83,857	274.5	90,141	298.5	94,166
227.0	76,300	251.0	84,005	275.0	90,252	299.0	94,212
227.5	76,472	251.5	84,152	275.5	90,362	299.5	94,257
228.0	76,643	252.0	84,298	276.0	90,471	300.0	94,299
228.5	76,814	252.5	84,444	276.5	90,579	300.5	94,338
229.0	76,985	253.0	84,589	277.0	90,686	301.0	94,375
229.5	77,155	253.5	84,733	277.5	90,793	301.5	94,409
230.0	77,325	254.0	84,877	278.0	90,898	302.0	94,440
230.5	77,495	254.5	85,020	278.5	91,002	302.5	94,467
231.0	77,664	255.0	85,163	279.0	91,105	303.0	94,491
231.5	77,832	255.5	85,304	279.5	91,207	303.5	94,509
232.0	78,000	256.0	85,446	280.0	91,308	304.0	94,522
232.5	78,168	256.5	85,586	280.5	91,408		
233.0	78,335	257.0	85,726	281.0	91,507		
233.5	78,501	257.5	85,865	281.5	91,605		
234.0	78,667	258.0	86,003	282.0	91,702		
234.5	78,833	258.5	86,141	282.5	91,798		
235.0	78,998	259.0	86,278	283.0	91,892		
235.5	79,163	259.5	86,414	283.5	91,986		
236.0	79,327	260.0	86,550	284.0	92,078		
236.5	79,491	260.5	86,685	284.5	92,169		
237.0	79,654	261.0	86,819	285.0	92,259		
237.5	79,817	261.5	86,952	285.5	92,348		
238.0	79,979	262.0	87,085	286.0	92,436		
238.5	80,141	262.5	87,217	286.5	92,522		
239.0	80,302	263.0	87,348	287.0	92,607		
239.5	80,462	263.5	87,478	287.5	92,691		
240.0	80,623	264.0	87,608	288.0	92,774		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.