

**DWT6 10'-30000 COMPARTMENT**  
**112,857 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.6	55	31.1	5,911	61.6	16,039	92.1	28,566	122.6	42,515
1.3	95	31.8	6,088	62.2	16,279	92.7	28,845	123.2	42,815
1.9	142	32.4	6,268	62.9	16,521	93.3	29,124	123.8	43,115
2.5	196	33.0	6,448	63.5	16,763	94.0	29,404	124.5	43,416
3.2	254	33.7	6,631	64.1	17,007	94.6	29,685	125.1	43,717
3.8	318	34.3	6,815	64.8	17,251	95.3	29,967	125.7	44,018
4.4	387	34.9	7,001	65.4	17,497	95.9	30,248	126.4	44,319
5.1	460	35.6	7,188	66.0	17,743	96.5	30,531	127.0	44,621
5.7	537	36.2	7,377	66.7	17,991	97.2	30,814	127.6	44,923
6.3	618	36.8	7,567	67.3	18,239	97.8	31,098	128.3	45,225
7.0	702	37.5	7,759	67.9	18,488	98.4	31,382	128.9	45,527
7.6	791	38.1	7,952	68.6	18,739	99.1	31,666	129.5	45,830
8.3	883	38.7	8,147	69.2	18,990	99.7	31,952	130.2	46,133
8.9	978	39.4	8,344	69.8	19,242	100.3	32,237	130.8	46,436
9.5	1,076	40.0	8,541	70.5	19,495	101.0	32,524	131.4	46,739
10.2	1,178	40.6	8,741	71.1	19,748	101.6	32,810	132.1	47,042
10.8	1,283	41.3	8,942	71.8	20,003	102.2	33,098	132.7	47,346
11.4	1,391	41.9	9,144	72.4	20,259	102.9	33,385	133.3	47,650
12.1	1,501	42.5	9,347	73.0	20,515	103.5	33,674	134.0	47,954
12.7	1,615	43.2	9,552	73.7	20,772	104.1	33,962	134.6	48,258
13.3	1,731	43.8	9,759	74.3	21,031	104.8	34,252	135.3	48,562
14.0	1,850	44.5	9,966	74.9	21,289	105.4	34,541	135.9	48,867
14.6	1,971	45.1	10,175	75.6	21,549	106.0	34,831	136.5	49,171
15.2	2,095	45.7	10,386	76.2	21,810	106.7	35,122	137.2	49,476
15.9	2,222	46.4	10,597	76.8	22,071	107.3	35,413	137.8	49,781
16.5	2,351	47.0	10,810	77.5	22,333	107.9	35,704	138.4	50,086
17.1	2,482	47.6	11,024	78.1	22,596	108.6	35,996	139.1	50,391
17.8	2,616	48.3	11,240	78.7	22,860	109.2	36,289	139.7	50,696
18.4	2,752	48.9	11,457	79.4	23,125	109.9	36,581	140.3	51,002
19.0	2,891	49.5	11,675	80.0	23,390	110.5	36,875	141.0	51,307
19.7	3,032	50.2	11,894	80.6	23,656	111.1	37,168	141.6	51,613
20.3	3,175	50.8	12,115	81.3	23,923	111.8	37,462	142.2	51,918
21.0	3,320	51.4	12,336	81.9	24,190	112.4	37,757	142.9	52,224
21.6	3,467	52.1	12,559	82.5	24,459	113.0	38,051	143.5	52,530
22.2	3,616	52.7	12,783	83.2	24,728	113.7	38,346	144.1	52,836
22.9	3,768	53.3	13,009	83.8	24,997	114.3	38,642	144.8	53,142
23.5	3,921	54.0	13,235	84.5	25,268	114.9	38,938	145.4	53,448
24.1	4,077	54.6	13,463	85.1	25,539	115.6	39,234	146.1	53,754
24.8	4,234	55.2	13,691	85.7	25,811	116.2	39,531	146.7	54,060
25.4	4,393	55.9	13,921	86.4	26,083	116.8	39,828	147.3	54,367
26.0	4,555	56.5	14,152	87.0	26,357	117.5	40,125	148.0	54,673
26.7	4,718	57.1	14,384	87.6	26,630	118.1	40,423	148.6	54,979
27.3	4,883	57.8	14,617	88.3	26,905	118.7	40,721	149.2	55,286
27.9	5,050	58.4	14,852	88.9	27,180	119.4	41,019	149.9	55,592
28.6	5,218	59.1	15,087	89.5	27,456	120.0	41,317	150.5	55,898
29.2	5,389	59.7	15,323	90.2	27,733	120.7	41,616	151.1	56,205
29.8	5,561	60.3	15,561	90.8	28,010	121.3	41,916	151.8	56,511
30.5	5,735	61.0	15,799	91.4	28,287	121.9	42,215	152.4	56,817

**DWT6 10'-30000 COMPARTMENT**  
**112,857 Liters**

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
153.0	57,124	183.5	71,701	214.0	85,551	244.5	97,900	275.0	107,735
153.7	57,430	184.1	71,999	214.6	85,826	245.1	98,135	275.6	107,903
154.3	57,737	184.8	72,297	215.3	86,101	245.7	98,368	276.2	108,069
154.9	58,043	185.4	72,595	215.9	86,375	246.4	98,601	276.9	108,233
155.6	58,349	186.1	72,893	216.5	86,649	247.0	98,832	277.5	108,395
156.2	58,655	186.7	73,190	217.2	86,922	247.6	99,063	278.1	108,555
156.8	58,962	187.3	73,486	217.8	87,194	248.3	99,292	278.8	108,714
157.5	59,268	188.0	73,783	218.4	87,465	248.9	99,520	279.4	108,870
158.1	59,574	188.6	74,079	219.1	87,736	249.6	99,747	280.0	109,025
158.8	59,880	189.2	74,375	219.7	88,006	250.2	99,973	280.7	109,177
159.4	60,186	189.9	74,670	220.3	88,276	250.8	100,198	281.3	109,328
160.0	60,492	190.5	74,965	221.0	88,544	251.5	100,421	281.9	109,476
160.7	60,798	191.1	75,260	221.6	88,812	252.1	100,644	282.6	109,622
161.3	61,103	191.8	75,554	222.3	89,079	252.7	100,865	283.2	109,766
161.9	61,409	192.4	75,847	222.9	89,346	253.4	101,085	283.8	109,908
162.6	61,714	193.0	76,141	223.5	89,612	254.0	101,303	284.5	110,047
163.2	62,020	193.7	76,434	224.2	89,877	254.6	101,521	285.1	110,185
163.8	62,325	194.3	76,726	224.8	90,141	255.3	101,737	285.8	110,320
164.5	62,630	194.9	77,019	225.4	90,404	255.9	101,952	286.4	110,452
165.1	62,936	195.6	77,310	226.1	90,667	256.5	102,165	287.0	110,583
165.7	63,240	196.2	77,601	226.7	90,928	257.2	102,378	287.7	110,711
166.4	63,545	196.8	77,892	227.3	91,189	257.8	102,589	288.3	110,836
167.0	63,850	197.5	78,183	228.0	91,450	258.4	102,798	288.9	110,959
167.6	64,154	198.1	78,473	228.6	91,709	259.1	103,007	289.6	111,079
168.3	64,459	198.8	78,762	229.2	91,967	259.7	103,214	290.2	111,196
168.9	64,763	199.4	79,051	229.9	92,225	260.4	103,419	290.8	111,311
169.5	65,067	200.0	79,339	230.5	92,482	261.0	103,624	291.5	111,423
170.2	65,371	200.7	79,627	231.1	92,738	261.6	103,826	292.1	111,532
170.8	65,675	201.3	79,915	231.8	92,993	262.3	104,028	292.7	111,639
171.4	65,978	201.9	80,202	232.4	93,247	262.9	104,228	293.4	111,742
172.1	66,281	202.6	80,488	233.0	93,501	263.5	104,426	294.0	111,842
172.7	66,584	203.2	80,774	233.7	93,753	264.2	104,624	294.6	111,939
173.4	66,887	203.8	81,060	234.3	94,005	264.8	104,819	295.3	112,033
174.0	67,190	204.5	81,345	234.9	94,255	265.4	105,013	295.9	112,123
174.6	67,493	205.1	81,629	235.6	94,505	266.1	105,206	296.5	112,209
175.3	67,795	205.7	81,913	236.2	94,754	266.7	105,397	297.2	112,292
175.9	68,097	206.4	82,196	236.9	95,002	267.3	105,587	297.8	112,371
176.5	68,399	207.0	82,479	237.5	95,249	268.0	105,775	298.4	112,446
177.2	68,700	207.6	82,761	238.1	95,495	268.6	105,961	299.1	112,517
177.8	69,001	208.3	83,043	238.8	95,740	269.2	106,146	299.7	112,583
178.4	69,302	208.9	83,324	239.4	95,984	269.9	106,329	300.4	112,644
179.1	69,603	209.6	83,605	240.0	96,227	270.5	106,511	301.0	112,700
179.7	69,904	210.2	83,884	240.7	96,469	271.1	106,691	301.6	112,751
180.3	70,204	210.8	84,164	241.3	96,710	271.8	106,869	302.3	112,794
181.0	70,504	211.5	84,442	241.9	96,950	272.4	107,046	302.9	112,831
181.6	70,804	212.1	84,720	242.6	97,189	273.0	107,221	303.5	112,857
182.2	71,103	212.7	84,998	243.2	97,427	273.7	107,394		
182.9	71,402	213.4	85,275	243.8	97,664	274.3	107,565		

# Fiber Glass Systems



## HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

## Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste      Description - PASTE02 - for Salt and Chloride Solutions  
7915 East Elm Street  
Houston, TX 77012  
Phone (713) 926-4780  
E-Mail Sales@KolorKut.com

## Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

## NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West  
Conroe, TX 77303  
Tel: 936-756-7731  
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.