

DWT6 10'-8000 COMPARTMENT
32,294 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	12	24.5	1,165	48.5	3,230	72.5	5,835	96.5	8,783
1.0	20	25.0	1,201	49.0	3,280	73.0	5,894	97.0	8,847
1.5	29	25.5	1,237	49.5	3,329	73.5	5,952	97.5	8,912
2.0	40	26.0	1,273	50.0	3,379	74.0	6,011	98.0	8,976
2.5	51	26.5	1,310	50.5	3,430	74.5	6,070	98.5	9,040
3.0	63	27.0	1,347	51.0	3,480	75.0	6,129	99.0	9,105
3.5	76	27.5	1,384	51.5	3,531	75.5	6,188	99.5	9,169
4.0	90	28.0	1,422	52.0	3,582	76.0	6,247	100.0	9,234
4.5	105	28.5	1,460	52.5	3,633	76.5	6,307	100.5	9,299
5.0	121	29.0	1,499	53.0	3,685	77.0	6,366	101.0	9,363
5.5	137	29.5	1,537	53.5	3,736	77.5	6,426	101.5	9,428
6.0	154	30.0	1,577	54.0	3,788	78.0	6,486	102.0	9,493
6.5	172	30.5	1,616	54.5	3,840	78.5	6,546	102.5	9,558
7.0	190	31.0	1,656	55.0	3,892	79.0	6,606	103.0	9,623
7.5	209	31.5	1,696	55.5	3,945	79.5	6,666	103.5	9,689
8.0	229	32.0	1,736	56.0	3,997	80.0	6,726	104.0	9,754
8.5	249	32.5	1,777	56.5	4,050	80.5	6,787	104.5	9,819
9.0	270	33.0	1,818	57.0	4,103	81.0	6,848	105.0	9,885
9.5	292	33.5	1,859	57.5	4,156	81.5	6,908	105.5	9,950
10.0	314	34.0	1,901	58.0	4,210	82.0	6,969	106.0	10,016
10.5	337	34.5	1,943	58.5	4,263	82.5	7,030	106.5	10,081
11.0	360	35.0	1,985	59.0	4,317	83.0	7,091	107.0	10,147
11.5	384	35.5	2,028	59.5	4,371	83.5	7,152	107.5	10,213
12.0	408	36.0	2,071	60.0	4,425	84.0	7,214	108.0	10,279
12.5	433	36.5	2,114	60.5	4,480	84.5	7,275	108.5	10,345
13.0	458	37.0	2,157	61.0	4,534	85.0	7,337	109.0	10,411
13.5	484	37.5	2,201	61.5	4,589	85.5	7,399	109.5	10,477
14.0	510	38.0	2,245	62.0	4,644	86.0	7,460	110.0	10,543
14.5	537	38.5	2,289	62.5	4,699	86.5	7,522	110.5	10,609
15.0	564	39.0	2,334	63.0	4,754	87.0	7,584	111.0	10,675
15.5	592	39.5	2,379	63.5	4,809	87.5	7,647	111.5	10,742
16.0	620	40.0	2,424	64.0	4,865	88.0	7,709	112.0	10,808
16.5	649	40.5	2,469	64.5	4,921	88.5	7,771	112.5	10,875
17.0	678	41.0	2,515	65.0	4,977	89.0	7,834	113.0	10,941
17.5	708	41.5	2,561	65.5	5,033	89.5	7,896	113.5	11,008
18.0	738	42.0	2,607	66.0	5,089	90.0	7,959	114.0	11,075
18.5	768	42.5	2,653	66.5	5,146	90.5	8,022	114.5	11,141
19.0	799	43.0	2,700	67.0	5,202	91.0	8,085	115.0	11,208
19.5	830	43.5	2,747	67.5	5,259	91.5	8,148	115.5	11,275
20.0	862	44.0	2,794	68.0	5,316	92.0	8,211	116.0	11,342
20.5	894	44.5	2,841	68.5	5,373	92.5	8,274	116.5	11,409
21.0	927	45.0	2,889	69.0	5,430	93.0	8,337	117.0	11,476
21.5	959	45.5	2,937	69.5	5,488	93.5	8,401	117.5	11,543
22.0	993	46.0	2,985	70.0	5,545	94.0	8,464	118.0	11,610
22.5	1,027	46.5	3,034	70.5	5,603	94.5	8,528	118.5	11,677
23.0	1,061	47.0	3,082	71.0	5,661	95.0	8,592	119.0	11,744
23.5	1,095	47.5	3,131	71.5	5,719	95.5	8,655	119.5	11,812
24.0	1,130	48.0	3,181	72.0	5,777	96.0	8,719	120.0	11,879

DWT6 10'-8000 COMPARTMENT
32,294 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	11,946	144.5	15,224	168.5	18,525	192.5	21,764
121.0	12,014	145.0	15,292	169.0	18,594	193.0	21,830
121.5	12,081	145.5	15,361	169.5	18,662	193.5	21,896
122.0	12,149	146.0	15,430	170.0	18,730	194.0	21,962
122.5	12,216	146.5	15,499	170.5	18,799	194.5	22,028
123.0	12,284	147.0	15,568	171.0	18,867	195.0	22,094
123.5	12,352	147.5	15,637	171.5	18,935	195.5	22,159
124.0	12,419	148.0	15,706	172.0	19,004	196.0	22,225
124.5	12,487	148.5	15,775	172.5	19,072	196.5	22,291
125.0	12,555	149.0	15,843	173.0	19,140	197.0	22,356
125.5	12,623	149.5	15,912	173.5	19,208	197.5	22,422
126.0	12,691	150.0	15,981	174.0	19,276	198.0	22,487
126.5	12,759	150.5	16,050	174.5	19,344	198.5	22,553
127.0	12,827	151.0	16,119	175.0	19,412	199.0	22,618
127.5	12,895	151.5	16,188	175.5	19,480	199.5	22,683
128.0	12,963	152.0	16,257	176.0	19,548	200.0	22,748
128.5	13,031	152.5	16,326	176.5	19,616	200.5	22,813
129.0	13,099	153.0	16,395	177.0	19,684	201.0	22,878
129.5	13,167	153.5	16,464	177.5	19,752	201.5	22,943
130.0	13,235	154.0	16,532	178.0	19,820	202.0	23,008
130.5	13,303	154.5	16,601	178.5	19,887	202.5	23,072
131.0	13,372	155.0	16,670	179.0	19,955	203.0	23,137
131.5	13,440	155.5	16,739	179.5	20,023	203.5	23,202
132.0	13,508	156.0	16,808	180.0	20,090	204.0	23,266
132.5	13,577	156.5	16,877	180.5	20,158	204.5	23,330
133.0	13,645	157.0	16,946	181.0	20,225	205.0	23,395
133.5	13,713	157.5	17,015	181.5	20,293	205.5	23,459
134.0	13,782	158.0	17,083	182.0	20,360	206.0	23,523
134.5	13,850	158.5	17,152	182.5	20,428	206.5	23,587
135.0	13,919	159.0	17,221	183.0	20,495	207.0	23,651
135.5	13,987	159.5	17,290	183.5	20,562	207.5	23,714
136.0	14,056	160.0	17,359	184.0	20,629	208.0	23,778
136.5	14,124	160.5	17,427	184.5	20,697	208.5	23,842
137.0	14,193	161.0	17,496	185.0	20,764	209.0	23,905
137.5	14,261	161.5	17,565	185.5	20,831	209.5	23,969
138.0	14,330	162.0	17,634	186.0	20,898	210.0	24,032
138.5	14,399	162.5	17,702	186.5	20,965	210.5	24,095
139.0	14,467	163.0	17,771	187.0	21,032	211.0	24,158
139.5	14,536	163.5	17,840	187.5	21,099	211.5	24,221
140.0	14,605	164.0	17,908	188.0	21,165	212.0	24,284
140.5	14,673	164.5	17,977	188.5	21,232	212.5	24,347
141.0	14,742	165.0	18,046	189.0	21,299	213.0	24,410
141.5	14,811	165.5	18,114	189.5	21,365	213.5	24,472
142.0	14,880	166.0	18,183	190.0	21,432	214.0	24,535
142.5	14,948	166.5	18,251	190.5	21,498	214.5	24,597
143.0	15,017	167.0	18,320	191.0	21,565	215.0	24,659
143.5	15,086	167.5	18,388	191.5	21,631	215.5	24,721
144.0	15,155	168.0	18,457	192.0	21,697	216.0	24,783

DWT6 10'-8000 COMPARTMENT
32,294 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	24,845	240.5	27,661	264.5	30,058	288.5	31,789
217.0	24,907	241.0	27,716	265.0	30,102	289.0	31,816
217.5	24,969	241.5	27,770	265.5	30,145	289.5	31,841
218.0	25,030	242.0	27,825	266.0	30,189	290.0	31,867
218.5	25,092	242.5	27,879	266.5	30,232	290.5	31,891
219.0	25,153	243.0	27,933	267.0	30,275	291.0	31,916
219.5	25,214	243.5	27,987	267.5	30,317	291.5	31,939
220.0	25,275	244.0	28,041	268.0	30,359	292.0	31,962
220.5	25,336	244.5	28,095	268.5	30,401	292.5	31,985
221.0	25,397	245.0	28,148	269.0	30,443	293.0	32,007
221.5	25,458	245.5	28,201	269.5	30,484	293.5	32,028
222.0	25,519	246.0	28,254	270.0	30,525	294.0	32,049
222.5	25,579	246.5	28,307	270.5	30,566	294.5	32,069
223.0	25,639	247.0	28,360	271.0	30,606	295.0	32,089
223.5	25,700	247.5	28,412	271.5	30,646	295.5	32,108
224.0	25,760	248.0	28,464	272.0	30,686	296.0	32,126
224.5	25,820	248.5	28,516	272.5	30,725	296.5	32,144
225.0	25,879	249.0	28,568	273.0	30,764	297.0	32,161
225.5	25,939	249.5	28,619	273.5	30,803	297.5	32,177
226.0	25,999	250.0	28,671	274.0	30,841	298.0	32,192
226.5	26,058	250.5	28,722	274.5	30,879	298.5	32,207
227.0	26,117	251.0	28,773	275.0	30,917	299.0	32,221
227.5	26,176	251.5	28,824	275.5	30,954	299.5	32,234
228.0	26,235	252.0	28,874	276.0	30,991	300.0	32,246
228.5	26,294	252.5	28,924	276.5	31,028	300.5	32,257
229.0	26,353	253.0	28,974	277.0	31,064	301.0	32,267
229.5	26,412	253.5	29,024	277.5	31,100	301.5	32,276
230.0	26,470	254.0	29,074	278.0	31,136	302.0	32,284
230.5	26,528	254.5	29,123	278.5	31,171	302.5	32,290
231.0	26,586	255.0	29,172	279.0	31,206	303.0	32,294
231.5	26,644	255.5	29,221	279.5	31,240		
232.0	26,702	256.0	29,270	280.0	31,274		
232.5	26,760	256.5	29,318	280.5	31,308		
233.0	26,817	257.0	29,366	281.0	31,341		
233.5	26,875	257.5	29,414	281.5	31,374		
234.0	26,932	258.0	29,462	282.0	31,407		
234.5	26,989	258.5	29,509	282.5	31,439		
235.0	27,046	259.0	29,556	283.0	31,470		
235.5	27,103	259.5	29,603	283.5	31,501		
236.0	27,159	260.0	29,650	284.0	31,532		
236.5	27,216	260.5	29,696	284.5	31,563		
237.0	27,272	261.0	29,742	285.0	31,593		
237.5	27,328	261.5	29,788	285.5	31,622		
238.0	27,384	262.0	29,834	286.0	31,651		
238.5	27,440	262.5	29,879	286.5	31,680		
239.0	27,495	263.0	29,924	287.0	31,708		
239.5	27,551	263.5	29,969	287.5	31,736		
240.0	27,606	264.0	30,014	288.0	31,763		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.