

DWT6 12'-25000 COMPARTMENT
96,471 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	35	24.5	2,974	48.5	8,002	72.5	14,298	96.5	21,489
1.0	56	25.0	3,062	49.0	8,122	73.0	14,439	97.0	21,646
1.5	81	25.5	3,151	49.5	8,243	73.5	14,582	97.5	21,803
2.0	109	26.0	3,241	50.0	8,363	74.0	14,724	98.0	21,961
2.5	140	26.5	3,331	50.5	8,485	74.5	14,867	98.5	22,120
3.0	173	27.0	3,423	51.0	8,607	75.0	15,010	99.0	22,278
3.5	208	27.5	3,515	51.5	8,729	75.5	15,154	99.5	22,437
4.0	246	28.0	3,608	52.0	8,852	76.0	15,298	100.0	22,596
4.5	285	28.5	3,701	52.5	8,976	76.5	15,442	100.5	22,755
5.0	327	29.0	3,796	53.0	9,100	77.0	15,587	101.0	22,914
5.5	370	29.5	3,891	53.5	9,224	77.5	15,732	101.5	23,074
6.0	415	30.0	3,987	54.0	9,349	78.0	15,877	102.0	23,234
6.5	461	30.5	4,083	54.5	9,475	78.5	16,023	102.5	23,394
7.0	510	31.0	4,181	55.0	9,601	79.0	16,169	103.0	23,555
7.5	560	31.5	4,279	55.5	9,727	79.5	16,315	103.5	23,715
8.0	611	32.0	4,378	56.0	9,854	80.0	16,462	104.0	23,876
8.5	664	32.5	4,477	56.5	9,982	80.5	16,609	104.5	24,038
9.0	718	33.0	4,577	57.0	10,110	81.0	16,757	105.0	24,199
9.5	774	33.5	4,678	57.5	10,238	81.5	16,905	105.5	24,361
10.0	831	34.0	4,780	58.0	10,367	82.0	17,053	106.0	24,523
10.5	890	34.5	4,882	58.5	10,497	82.5	17,202	106.5	24,685
11.0	949	35.0	4,985	59.0	10,626	83.0	17,350	107.0	24,847
11.5	1,010	35.5	5,089	59.5	10,757	83.5	17,500	107.5	25,010
12.0	1,073	36.0	5,193	60.0	10,888	84.0	17,649	108.0	25,173
12.5	1,136	36.5	5,298	60.5	11,019	84.5	17,799	108.5	25,336
13.0	1,201	37.0	5,404	61.0	11,151	85.0	17,949	109.0	25,499
13.5	1,267	37.5	5,510	61.5	11,283	85.5	18,100	109.5	25,663
14.0	1,334	38.0	5,617	62.0	11,415	86.0	18,251	110.0	25,826
14.5	1,402	38.5	5,725	62.5	11,548	86.5	18,402	110.5	25,990
15.0	1,471	39.0	5,833	63.0	11,682	87.0	18,553	111.0	26,155
15.5	1,541	39.5	5,942	63.5	11,816	87.5	18,705	111.5	26,319
16.0	1,613	40.0	6,051	64.0	11,950	88.0	18,857	112.0	26,484
16.5	1,685	40.5	6,161	64.5	12,085	88.5	19,010	112.5	26,649
17.0	1,758	41.0	6,272	65.0	12,220	89.0	19,162	113.0	26,814
17.5	1,833	41.5	6,383	65.5	12,356	89.5	19,315	113.5	26,979
18.0	1,908	42.0	6,495	66.0	12,492	90.0	19,469	114.0	27,144
18.5	1,985	42.5	6,608	66.5	12,628	90.5	19,622	114.5	27,310
19.0	2,062	43.0	6,721	67.0	12,765	91.0	19,776	115.0	27,476
19.5	2,141	43.5	6,834	67.5	12,902	91.5	19,930	115.5	27,642
20.0	2,220	44.0	6,949	68.0	13,040	92.0	20,085	116.0	27,808
20.5	2,300	44.5	7,063	68.5	13,178	92.5	20,240	116.5	27,975
21.0	2,381	45.0	7,179	69.0	13,317	93.0	20,395	117.0	28,141
21.5	2,463	45.5	7,295	69.5	13,456	93.5	20,550	117.5	28,308
22.0	2,546	46.0	7,411	70.0	13,595	94.0	20,706	118.0	28,475
22.5	2,630	46.5	7,528	70.5	13,735	94.5	20,862	118.5	28,643
23.0	2,715	47.0	7,646	71.0	13,875	95.0	21,018	119.0	28,810
23.5	2,800	47.5	7,764	71.5	14,016	95.5	21,175	119.5	28,978
24.0	2,887	48.0	7,883	72.0	14,156	96.0	21,331	120.0	29,146

DWT6 12'-25000 COMPARTMENT
96,471 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	29,314	144.5	37,558	168.5	46,031	192.5	54,550	216.5	62,936
121.0	29,482	145.0	37,733	169.0	46,209	193.0	54,727	217.0	63,108
121.5	29,650	145.5	37,908	169.5	46,386	193.5	54,904	217.5	63,280
122.0	29,819	146.0	38,083	170.0	46,564	194.0	55,080	218.0	63,452
122.5	29,987	146.5	38,258	170.5	46,742	194.5	55,257	218.5	63,623
123.0	30,156	147.0	38,433	171.0	46,920	195.0	55,433	219.0	63,795
123.5	30,325	147.5	38,609	171.5	47,097	195.5	55,610	219.5	63,966
124.0	30,494	148.0	38,784	172.0	47,275	196.0	55,786	220.0	64,137
124.5	30,664	148.5	38,960	172.5	47,453	196.5	55,962	220.5	64,308
125.0	30,833	149.0	39,135	173.0	47,630	197.0	56,138	221.0	64,479
125.5	31,003	149.5	39,311	173.5	47,808	197.5	56,314	221.5	64,650
126.0	31,173	150.0	39,487	174.0	47,986	198.0	56,490	222.0	64,820
126.5	31,343	150.5	39,662	174.5	48,164	198.5	56,666	222.5	64,990
127.0	31,513	151.0	39,838	175.0	48,341	199.0	56,842	223.0	65,161
127.5	31,684	151.5	40,014	175.5	48,519	199.5	57,018	223.5	65,331
128.0	31,854	152.0	40,190	176.0	48,697	200.0	57,194	224.0	65,500
128.5	32,025	152.5	40,366	176.5	48,875	200.5	57,369	224.5	65,670
129.0	32,196	153.0	40,543	177.0	49,052	201.0	57,545	225.0	65,840
129.5	32,367	153.5	40,719	177.5	49,230	201.5	57,720	225.5	66,009
130.0	32,538	154.0	40,895	178.0	49,408	202.0	57,896	226.0	66,178
130.5	32,709	154.5	41,072	178.5	49,586	202.5	58,071	226.5	66,347
131.0	32,881	155.0	41,248	179.0	49,763	203.0	58,246	227.0	66,516
131.5	33,052	155.5	41,425	179.5	49,941	203.5	58,421	227.5	66,685
132.0	33,224	156.0	41,601	180.0	50,119	204.0	58,596	228.0	66,853
132.5	33,396	156.5	41,778	180.5	50,296	204.5	58,771	228.5	67,022
133.0	33,568	157.0	41,954	181.0	50,474	205.0	58,946	229.0	67,190
133.5	33,740	157.5	42,131	181.5	50,651	205.5	59,121	229.5	67,358
134.0	33,912	158.0	42,308	182.0	50,829	206.0	59,295	230.0	67,526
134.5	34,085	158.5	42,485	182.5	51,007	206.5	59,470	230.5	67,693
135.0	34,257	159.0	42,662	183.0	51,184	207.0	59,644	231.0	67,861
135.5	34,430	159.5	42,839	183.5	51,362	207.5	59,819	231.5	68,028
136.0	34,603	160.0	43,016	184.0	51,539	208.0	59,993	232.0	68,195
136.5	34,776	160.5	43,193	184.5	51,717	208.5	60,167	232.5	68,362
137.0	34,949	161.0	43,370	185.0	51,894	209.0	60,341	233.0	68,528
137.5	35,122	161.5	43,547	185.5	52,071	209.5	60,515	233.5	68,695
138.0	35,295	162.0	43,724	186.0	52,249	210.0	60,689	234.0	68,861
138.5	35,469	162.5	43,902	186.5	52,426	210.5	60,862	234.5	69,027
139.0	35,642	163.0	44,079	187.0	52,603	211.0	61,036	235.0	69,193
139.5	35,816	163.5	44,256	187.5	52,781	211.5	61,209	235.5	69,359
140.0	35,989	164.0	44,434	188.0	52,958	212.0	61,382	236.0	69,524
140.5	36,163	164.5	44,611	188.5	53,135	212.5	61,556	236.5	69,689
141.0	36,337	165.0	44,788	189.0	53,312	213.0	61,729	237.0	69,854
141.5	36,511	165.5	44,966	189.5	53,489	213.5	61,902	237.5	70,019
142.0	36,686	166.0	45,143	190.0	53,666	214.0	62,074	238.0	70,184
142.5	36,860	166.5	45,321	190.5	53,843	214.5	62,247	238.5	70,348
143.0	37,034	167.0	45,498	191.0	54,020	215.0	62,419	239.0	70,512
143.5	37,209	167.5	45,676	191.5	54,197	215.5	62,592	239.5	70,676
144.0	37,384	168.0	45,854	192.0	54,374	216.0	62,764	240.0	70,840

DWT6 12'-25000 COMPARTMENT
96,471 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
240.5	71,003	264.5	78,551	288.5	85,347	312.5	91,089	336.5	95,284
241.0	71,167	265.0	78,701	289.0	85,478	313.0	91,194	337.0	95,349
241.5	71,330	265.5	78,851	289.5	85,609	313.5	91,299	337.5	95,412
242.0	71,493	266.0	79,000	290.0	85,740	314.0	91,403	338.0	95,474
242.5	71,655	266.5	79,150	290.5	85,870	314.5	91,507	338.5	95,535
243.0	71,817	267.0	79,298	291.0	86,000	315.0	91,610	339.0	95,595
243.5	71,980	267.5	79,447	291.5	86,129	315.5	91,712	339.5	95,653
244.0	72,141	268.0	79,595	292.0	86,258	316.0	91,813	340.0	95,710
244.5	72,303	268.5	79,743	292.5	86,386	316.5	91,914	340.5	95,765
245.0	72,465	269.0	79,890	293.0	86,514	317.0	92,014	341.0	95,819
245.5	72,626	269.5	80,037	293.5	86,642	317.5	92,114	341.5	95,872
246.0	72,787	270.0	80,184	294.0	86,769	318.0	92,212	342.0	95,923
246.5	72,947	270.5	80,331	294.5	86,895	318.5	92,310	342.5	95,973
247.0	73,108	271.0	80,477	295.0	87,021	319.0	92,408	343.0	96,021
247.5	73,268	271.5	80,622	295.5	87,146	319.5	92,504	343.5	96,067
248.0	73,428	272.0	80,768	296.0	87,271	320.0	92,600	344.0	96,112
248.5	73,588	272.5	80,913	296.5	87,396	320.5	92,695	344.5	96,155
249.0	73,747	273.0	81,057	297.0	87,520	321.0	92,789	345.0	96,196
249.5	73,906	273.5	81,202	297.5	87,643	321.5	92,883	345.5	96,235
250.0	74,065	274.0	81,345	298.0	87,766	322.0	92,975	346.0	96,272
250.5	74,224	274.5	81,489	298.5	87,888	322.5	93,067	346.5	96,307
251.0	74,382	275.0	81,632	299.0	88,010	323.0	93,159	347.0	96,340
251.5	74,540	275.5	81,775	299.5	88,132	323.5	93,249	347.5	96,370
252.0	74,698	276.0	81,917	300.0	88,252	324.0	93,339	348.0	96,397
252.5	74,856	276.5	82,059	300.5	88,373	324.5	93,427	348.5	96,422
253.0	75,013	277.0	82,201	301.0	88,492	325.0	93,515	349.0	96,443
253.5	75,170	277.5	82,342	301.5	88,612	325.5	93,602	349.5	96,459
254.0	75,327	278.0	82,483	302.0	88,730	326.0	93,689	350.0	96,471
254.5	75,483	278.5	82,624	302.5	88,848	326.5	93,774		
255.0	75,639	279.0	82,764	303.0	88,966	327.0	93,859		
255.5	75,795	279.5	82,903	303.5	89,083	327.5	93,942		
256.0	75,951	280.0	83,043	304.0	89,199	328.0	94,025		
256.5	76,106	280.5	83,181	304.5	89,315	328.5	94,107		
257.0	76,261	281.0	83,320	305.0	89,431	329.0	94,188		
257.5	76,416	281.5	83,458	305.5	89,545	329.5	94,268		
258.0	76,571	282.0	83,596	306.0	89,660	330.0	94,347		
258.5	76,725	282.5	83,733	306.5	89,773	330.5	94,425		
259.0	76,879	283.0	83,870	307.0	89,886	331.0	94,503		
259.5	77,032	283.5	84,006	307.5	89,998	331.5	94,579		
260.0	77,185	284.0	84,142	308.0	90,110	332.0	94,654		
260.5	77,338	284.5	84,278	308.5	90,221	332.5	94,728		
261.0	77,491	285.0	84,413	309.0	90,332	333.0	94,802		
261.5	77,643	285.5	84,547	309.5	90,442	333.5	94,874		
262.0	77,796	286.0	84,682	310.0	90,551	334.0	94,945		
262.5	77,947	286.5	84,816	310.5	90,660	334.5	95,015		
263.0	78,099	287.0	84,949	311.0	90,768	335.0	95,084		
263.5	78,250	287.5	85,082	311.5	90,876	335.5	95,152		
264.0	78,401	288.0	85,214	312.0	90,982	336.0	95,219		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.