

DWT6 12'-30000 COMPARTMENT
114,120 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	42	24.5	3,541	48.5	9,511	72.5	16,971	96.5	25,478
1.0	67	25.0	3,646	49.0	9,653	73.0	17,138	97.0	25,664
1.5	97	25.5	3,751	49.5	9,796	73.5	17,307	97.5	25,850
2.0	131	26.0	3,858	50.0	9,939	74.0	17,475	98.0	26,037
2.5	167	26.5	3,966	50.5	10,083	74.5	17,644	98.5	26,224
3.0	207	27.0	4,074	51.0	10,228	75.0	17,814	99.0	26,411
3.5	249	27.5	4,184	51.5	10,373	75.5	17,984	99.5	26,598
4.0	293	28.0	4,294	52.0	10,519	76.0	18,154	100.0	26,786
4.5	340	28.5	4,405	52.5	10,666	76.5	18,325	100.5	26,975
5.0	390	29.0	4,518	53.0	10,813	77.0	18,496	101.0	27,163
5.5	441	29.5	4,631	53.5	10,960	77.5	18,668	101.5	27,352
6.0	495	30.0	4,745	54.0	11,108	78.0	18,840	102.0	27,541
6.5	551	30.5	4,859	54.5	11,257	78.5	19,013	102.5	27,730
7.0	608	31.0	4,975	55.0	11,407	79.0	19,185	103.0	27,920
7.5	668	31.5	5,092	55.5	11,557	79.5	19,359	103.5	28,110
8.0	729	32.0	5,209	56.0	11,707	80.0	19,533	104.0	28,300
8.5	792	32.5	5,327	56.5	11,858	80.5	19,707	104.5	28,491
9.0	857	33.0	5,446	57.0	12,010	81.0	19,881	105.0	28,682
9.5	923	33.5	5,566	57.5	12,162	81.5	20,056	105.5	28,873
10.0	991	34.0	5,687	58.0	12,315	82.0	20,232	106.0	29,064
10.5	1,061	34.5	5,808	58.5	12,468	82.5	20,407	106.5	29,256
11.0	1,132	35.0	5,931	59.0	12,622	83.0	20,583	107.0	29,448
11.5	1,205	35.5	6,054	59.5	12,777	83.5	20,760	107.5	29,640
12.0	1,279	36.0	6,178	60.0	12,932	84.0	20,937	108.0	29,832
12.5	1,355	36.5	6,302	60.5	13,087	84.5	21,114	108.5	30,025
13.0	1,432	37.0	6,428	61.0	13,243	85.0	21,292	109.0	30,218
13.5	1,510	37.5	6,554	61.5	13,400	85.5	21,470	109.5	30,411
14.0	1,590	38.0	6,681	62.0	13,557	86.0	21,648	110.0	30,605
14.5	1,671	38.5	6,809	62.5	13,714	86.5	21,827	110.5	30,798
15.0	1,753	39.0	6,937	63.0	13,872	87.0	22,006	111.0	30,992
15.5	1,837	39.5	7,066	63.5	14,031	87.5	22,186	111.5	31,187
16.0	1,922	40.0	7,196	64.0	14,190	88.0	22,366	112.0	31,381
16.5	2,008	40.5	7,327	64.5	14,350	88.5	22,546	112.5	31,576
17.0	2,095	41.0	7,458	65.0	14,510	89.0	22,727	113.0	31,771
17.5	2,184	41.5	7,590	65.5	14,671	89.5	22,908	113.5	31,966
18.0	2,274	42.0	7,723	66.0	14,832	90.0	23,089	114.0	32,162
18.5	2,365	42.5	7,857	66.5	14,994	90.5	23,271	114.5	32,357
19.0	2,457	43.0	7,991	67.0	15,156	91.0	23,453	115.0	32,553
19.5	2,550	43.5	8,126	67.5	15,318	91.5	23,635	115.5	32,750
20.0	2,644	44.0	8,261	68.0	15,481	92.0	23,818	116.0	32,946
20.5	2,740	44.5	8,397	68.5	15,645	92.5	24,001	116.5	33,143
21.0	2,836	45.0	8,534	69.0	15,809	93.0	24,184	117.0	33,340
21.5	2,934	45.5	8,672	69.5	15,974	93.5	24,368	117.5	33,537
22.0	3,032	46.0	8,810	70.0	16,139	94.0	24,552	118.0	33,734
22.5	3,132	46.5	8,949	70.5	16,304	94.5	24,737	118.5	33,932
23.0	3,233	47.0	9,089	71.0	16,470	95.0	24,921	119.0	34,129
23.5	3,335	47.5	9,229	71.5	16,636	95.5	25,106	119.5	34,327
24.0	3,437	48.0	9,370	72.0	16,803	96.0	25,292	120.0	34,526

DWT6 12'-30000 COMPARTMENT
114,120 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	34,724	144.5	44,459	168.5	54,459	192.5	64,513	216.5	74,412
121.0	34,923	145.0	44,666	169.0	54,669	193.0	64,721	217.0	74,615
121.5	35,122	145.5	44,872	169.5	54,878	193.5	64,930	217.5	74,818
122.0	35,321	146.0	45,079	170.0	55,088	194.0	65,138	218.0	75,021
122.5	35,520	146.5	45,285	170.5	55,298	194.5	65,347	218.5	75,223
123.0	35,719	147.0	45,492	171.0	55,507	195.0	65,555	219.0	75,426
123.5	35,919	147.5	45,699	171.5	55,717	195.5	65,763	219.5	75,628
124.0	36,119	148.0	45,906	172.0	55,927	196.0	65,971	220.0	75,830
124.5	36,319	148.5	46,113	172.5	56,137	196.5	66,179	220.5	76,032
125.0	36,519	149.0	46,320	173.0	56,346	197.0	66,387	221.0	76,233
125.5	36,720	149.5	46,528	173.5	56,556	197.5	66,595	221.5	76,435
126.0	36,920	150.0	46,735	174.0	56,766	198.0	66,803	222.0	76,636
126.5	37,121	150.5	46,943	174.5	56,976	198.5	67,010	222.5	76,837
127.0	37,322	151.0	47,150	175.0	57,185	199.0	67,218	223.0	77,038
127.5	37,523	151.5	47,358	175.5	57,395	199.5	67,425	223.5	77,239
128.0	37,725	152.0	47,566	176.0	57,605	200.0	67,633	224.0	77,440
128.5	37,926	152.5	47,774	176.5	57,815	200.5	67,840	224.5	77,640
129.0	38,128	153.0	47,982	177.0	58,024	201.0	68,047	225.0	77,840
129.5	38,330	153.5	48,190	177.5	58,234	201.5	68,254	225.5	78,040
130.0	38,532	154.0	48,398	178.0	58,444	202.0	68,461	226.0	78,240
130.5	38,734	154.5	48,606	178.5	58,654	202.5	68,668	226.5	78,440
131.0	38,937	155.0	48,814	179.0	58,863	203.0	68,875	227.0	78,639
131.5	39,139	155.5	49,023	179.5	59,073	203.5	69,082	227.5	78,839
132.0	39,342	156.0	49,231	180.0	59,283	204.0	69,288	228.0	79,038
132.5	39,545	156.5	49,439	180.5	59,492	204.5	69,495	228.5	79,236
133.0	39,748	157.0	49,648	181.0	59,702	205.0	69,701	229.0	79,435
133.5	39,951	157.5	49,857	181.5	59,912	205.5	69,908	229.5	79,633
134.0	40,155	158.0	50,065	182.0	60,121	206.0	70,114	230.0	79,832
134.5	40,358	158.5	50,274	182.5	60,331	206.5	70,320	230.5	80,030
135.0	40,562	159.0	50,483	183.0	60,540	207.0	70,526	231.0	80,227
135.5	40,766	159.5	50,692	183.5	60,750	207.5	70,731	231.5	80,425
136.0	40,970	160.0	50,901	184.0	60,959	208.0	70,937	232.0	80,622
136.5	41,174	160.5	51,110	184.5	61,169	208.5	71,142	232.5	80,819
137.0	41,378	161.0	51,319	185.0	61,378	209.0	71,348	233.0	81,016
137.5	41,583	161.5	51,528	185.5	61,587	209.5	71,553	233.5	81,213
138.0	41,787	162.0	51,737	186.0	61,797	210.0	71,758	234.0	81,409
138.5	41,992	162.5	51,946	186.5	62,006	210.5	71,963	234.5	81,605
139.0	42,197	163.0	52,155	187.0	62,215	211.0	72,168	235.0	81,801
139.5	42,402	163.5	52,364	187.5	62,424	211.5	72,373	235.5	81,997
140.0	42,607	164.0	52,574	188.0	62,633	212.0	72,577	236.0	82,192
140.5	42,812	164.5	52,783	188.5	62,842	212.5	72,782	236.5	82,388
141.0	43,018	165.0	52,993	189.0	63,051	213.0	72,986	237.0	82,582
141.5	43,223	165.5	53,202	189.5	63,260	213.5	73,190	237.5	82,777
142.0	43,429	166.0	53,411	190.0	63,469	214.0	73,394	238.0	82,972
142.5	43,635	166.5	53,621	190.5	63,678	214.5	73,598	238.5	83,166
143.0	43,841	167.0	53,830	191.0	63,887	215.0	73,802	239.0	83,360
143.5	44,047	167.5	54,040	191.5	64,096	215.5	74,005	239.5	83,554
144.0	44,253	168.0	54,250	192.0	64,304	216.0	74,209	240.0	83,747

DWT6 12'-30000 COMPARTMENT
114,120 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
240.5	83,940	264.5	92,864	288.5	100,909	312.5	107,719	336.5	112,706
241.0	84,133	265.0	93,041	289.0	101,065	313.0	107,844	337.0	112,783
241.5	84,326	265.5	93,218	289.5	101,220	313.5	107,968	337.5	112,859
242.0	84,518	266.0	93,395	290.0	101,375	314.0	108,092	338.0	112,932
242.5	84,710	266.5	93,572	290.5	101,529	314.5	108,215	338.5	113,005
243.0	84,902	267.0	93,748	291.0	101,683	315.0	108,337	339.0	113,076
243.5	85,094	267.5	93,924	291.5	101,836	315.5	108,459	339.5	113,145
244.0	85,285	268.0	94,099	292.0	101,989	316.0	108,579	340.0	113,213
244.5	85,476	268.5	94,274	292.5	102,141	316.5	108,699	340.5	113,279
245.0	85,667	269.0	94,448	293.0	102,293	317.0	108,818	341.0	113,343
245.5	85,857	269.5	94,622	293.5	102,444	317.5	108,936	341.5	113,406
246.0	86,048	270.0	94,796	294.0	102,594	318.0	109,053	342.0	113,467
246.5	86,238	270.5	94,969	294.5	102,744	318.5	109,170	342.5	113,526
247.0	86,427	271.0	95,142	295.0	102,893	319.0	109,285	343.0	113,584
247.5	86,617	271.5	95,314	295.5	103,042	319.5	109,400	343.5	113,639
248.0	86,806	272.0	95,487	296.0	103,190	320.0	109,514	344.0	113,692
248.5	86,994	272.5	95,658	296.5	103,338	320.5	109,627	344.5	113,743
249.0	87,183	273.0	95,829	297.0	103,485	321.0	109,739	345.0	113,792
249.5	87,371	273.5	96,000	297.5	103,631	321.5	109,850	345.5	113,839
250.0	87,559	274.0	96,170	298.0	103,777	322.0	109,960	346.0	113,883
250.5	87,746	274.5	96,340	298.5	103,922	322.5	110,069	346.5	113,925
251.0	87,934	275.0	96,510	299.0	104,066	323.0	110,178	347.0	113,964
251.5	88,120	275.5	96,679	299.5	104,210	323.5	110,285	347.5	114,000
252.0	88,307	276.0	96,847	300.0	104,353	324.0	110,392	348.0	114,033
252.5	88,493	276.5	97,015	300.5	104,496	324.5	110,497	348.5	114,062
253.0	88,679	277.0	97,183	301.0	104,638	325.0	110,602	349.0	114,087
253.5	88,865	277.5	97,350	301.5	104,779	325.5	110,705	349.5	114,107
254.0	89,050	278.0	97,517	302.0	104,920	326.0	110,808	350.0	114,120
254.5	89,235	278.5	97,683	302.5	105,060	326.5	110,909		
255.0	89,420	279.0	97,849	303.0	105,200	327.0	111,010		
255.5	89,604	279.5	98,015	303.5	105,339	327.5	111,109		
256.0	89,788	280.0	98,180	304.0	105,477	328.0	111,208		
256.5	89,972	280.5	98,344	304.5	105,614	328.5	111,305		
257.0	90,155	281.0	98,508	305.0	105,751	329.0	111,402		
257.5	90,339	281.5	98,672	305.5	105,887	329.5	111,497		
258.0	90,521	282.0	98,835	306.0	106,023	330.0	111,591		
258.5	90,704	282.5	98,997	306.5	106,157	330.5	111,684		
259.0	90,885	283.0	99,159	307.0	106,291	331.0	111,776		
259.5	91,067	283.5	99,321	307.5	106,425	331.5	111,867		
260.0	91,248	284.0	99,482	308.0	106,557	332.0	111,956		
260.5	91,429	284.5	99,642	308.5	106,689	332.5	112,045		
261.0	91,610	285.0	99,802	309.0	106,821	333.0	112,132		
261.5	91,790	285.5	99,962	309.5	106,951	333.5	112,218		
262.0	91,970	286.0	100,121	310.0	107,081	334.0	112,302		
262.5	92,149	286.5	100,280	310.5	107,210	334.5	112,386		
263.0	92,329	287.0	100,438	311.0	107,338	335.0	112,468		
263.5	92,507	287.5	100,595	311.5	107,466	335.5	112,549		
264.0	92,686	288.0	100,752	312.0	107,593	336.0	112,628		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.