


FLOW RATE - G.P.M.		
.85 s.g.	.90 s.g.	.95 s.g.
373	281	125



**USE PARAMETERS:**

PROPER PERFORMANCE OF THE OIL WATER SEPARATOR AND THE QUALITY OF THE EFFLUENT IS BASED UPON THE OPERATIONAL, FUNCTIONAL, & INSTALLATION REQUIREMENTS AS DETAILED IN THE FOLLOWING **CSI** PUBLICATIONS.

- OIL/WATER SEPARATOR PRODUCT LITERATURE.
- INSTALLATION INSTRUCTIONS: FRP UNDERGROUND STORAGE TANKS. (CSI 6001)
- INSTALLATION AND START-UP INSTRUCTIONS FOR UNDERGROUND OWS TANKS. (OWS 2012)

**PUB NO. 655C10DWULCSI-10 JANUARY 2009**

**DESIGN PARAMETERS:**

THE SEPARATOR IS DESIGNED FOR:

- MAXIMUM INFLUENT CAPACITY (IN) \_\_\_\_\_ PPM
- MAXIMUM EFFLUENT CAPACITY (OUT) \_\_\_\_\_ PPM
- MAXIMUM FLOW RATE \_\_\_\_\_ GPM
- NUMBER OF INSTALLED COALESCER PACKS \_\_\_\_\_

CUSTOMER SIGNATURE ACKNOWLEDGES AND AGREES TO THE USE AND DESIGN PARAMETERS AS DETAILED IN THIS DRAWING AND IN THE REFERENCED PUBLICATIONS AND HEREBY APPROVES FABRICATION. ANY DEVIATION AS OUTLINED MUST BE APPROVED BY **CSI** IN WRITING PRIOR TO MANUFACTURING.

CUSTOMER APPROVAL SIGNATURE:

DATE:

COMPANY:

JOB NAME:

**CONTAINMENT SOLUTIONS**

**6'-5,500 Gallon DWT6  
 ULCSI-10 Oil Water Separator**

SPILL CAPACITY:	ACTUAL CAPACITY:	NOMINAL WEIGHT:
4,375 GAL	5,469 GAL	6,355 LBS