

DWT6 8'-1000 COMPARTMENT
36,703 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	24	24.5	2,028	48.5	5,453	72.5	9,694	96.5	14,415
1.0	39	25.0	2,088	49.0	5,534	73.0	9,789	97.0	14,517
1.5	56	25.5	2,149	49.5	5,616	73.5	9,884	97.5	14,618
2.0	75	26.0	2,210	50.0	5,698	74.0	9,979	98.0	14,720
2.5	96	26.5	2,271	50.5	5,780	74.5	10,074	98.5	14,821
3.0	118	27.0	2,334	51.0	5,863	75.0	10,169	99.0	14,923
3.5	143	27.5	2,396	51.5	5,946	75.5	10,264	99.5	15,025
4.0	168	28.0	2,460	52.0	6,030	76.0	10,360	100.0	15,127
4.5	195	28.5	2,524	52.5	6,113	76.5	10,456	100.5	15,229
5.0	223	29.0	2,588	53.0	6,197	77.0	10,552	101.0	15,331
5.5	253	29.5	2,653	53.5	6,282	77.5	10,648	101.5	15,433
6.0	284	30.0	2,718	54.0	6,366	78.0	10,745	102.0	15,535
6.5	316	30.5	2,784	54.5	6,451	78.5	10,841	102.5	15,637
7.0	349	31.0	2,850	55.0	6,537	79.0	10,938	103.0	15,740
7.5	383	31.5	2,917	55.5	6,622	79.5	11,035	103.5	15,842
8.0	418	32.0	2,985	56.0	6,708	80.0	11,132	104.0	15,945
8.5	454	32.5	3,052	56.5	6,795	80.5	11,229	104.5	16,047
9.0	491	33.0	3,121	57.0	6,881	81.0	11,327	105.0	16,150
9.5	529	33.5	3,190	57.5	6,968	81.5	11,424	105.5	16,252
10.0	568	34.0	3,259	58.0	7,055	82.0	11,522	106.0	16,355
10.5	608	34.5	3,329	58.5	7,142	82.5	11,620	106.5	16,457
11.0	648	35.0	3,399	59.0	7,230	83.0	11,718	107.0	16,560
11.5	690	35.5	3,469	59.5	7,318	83.5	11,816	107.5	16,663
12.0	732	36.0	3,541	60.0	7,406	84.0	11,914	108.0	16,766
12.5	776	36.5	3,612	60.5	7,495	84.5	12,013	108.5	16,868
13.0	820	37.0	3,684	61.0	7,584	85.0	12,112	109.0	16,971
13.5	865	37.5	3,757	61.5	7,673	85.5	12,210	109.5	17,074
14.0	910	38.0	3,829	62.0	7,762	86.0	12,309	110.0	17,177
14.5	957	38.5	3,903	62.5	7,852	86.5	12,408	110.5	17,280
15.0	1,004	39.0	3,976	63.0	7,941	87.0	12,508	111.0	17,383
15.5	1,052	39.5	4,051	63.5	8,032	87.5	12,607	111.5	17,486
16.0	1,100	40.0	4,125	64.0	8,122	88.0	12,707	112.0	17,589
16.5	1,150	40.5	4,200	64.5	8,213	88.5	12,806	112.5	17,692
17.0	1,200	41.0	4,276	65.0	8,303	89.0	12,906	113.0	17,795
17.5	1,250	41.5	4,351	65.5	8,395	89.5	13,006	113.5	17,898
18.0	1,302	42.0	4,427	66.0	8,486	90.0	13,106	114.0	18,001
18.5	1,354	42.5	4,504	66.5	8,578	90.5	13,206	114.5	18,104
19.0	1,407	43.0	4,581	67.0	8,669	91.0	13,306	115.0	18,207
19.5	1,460	43.5	4,658	67.5	8,761	91.5	13,406	115.5	18,310
20.0	1,514	44.0	4,736	68.0	8,854	92.0	13,507	116.0	18,413
20.5	1,569	44.5	4,814	68.5	8,946	92.5	13,607	116.5	18,516
21.0	1,624	45.0	4,893	69.0	9,039	93.0	13,708	117.0	18,619
21.5	1,680	45.5	4,972	69.5	9,132	93.5	13,809	117.5	18,722
22.0	1,737	46.0	5,051	70.0	9,225	94.0	13,910	118.0	18,825
22.5	1,794	46.5	5,131	70.5	9,319	94.5	14,010	118.5	18,928
23.0	1,851	47.0	5,211	71.0	9,412	95.0	14,112	119.0	19,031
23.5	1,910	47.5	5,291	71.5	9,506	95.5	14,213	119.5	19,134
24.0	1,969	48.0	5,372	72.0	9,600	96.0	14,314	120.0	19,237

DWT6 8'-1000 COMPARTMENT
36,703 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	19,340	144.5	24,215	168.5	28,779	192.5	32,742	216.5	35,710
121.0	19,443	145.0	24,314	169.0	28,869	193.0	32,815	217.0	35,757
121.5	19,546	145.5	24,413	169.5	28,959	193.5	32,888	217.5	35,803
122.0	19,649	146.0	24,512	170.0	29,048	194.0	32,961	218.0	35,848
122.5	19,752	146.5	24,611	170.5	29,137	194.5	33,034	218.5	35,893
123.0	19,855	147.0	24,709	171.0	29,226	195.0	33,106	219.0	35,937
123.5	19,958	147.5	24,808	171.5	29,314	195.5	33,177	219.5	35,980
124.0	20,060	148.0	24,906	172.0	29,402	196.0	33,248	220.0	36,022
124.5	20,163	148.5	25,004	172.5	29,490	196.5	33,319	220.5	36,064
125.0	20,266	149.0	25,102	173.0	29,578	197.0	33,389	221.0	36,104
125.5	20,368	149.5	25,200	173.5	29,665	197.5	33,458	221.5	36,144
126.0	20,471	150.0	25,298	174.0	29,752	198.0	33,528	222.0	36,183
126.5	20,574	150.5	25,396	174.5	29,839	198.5	33,596	222.5	36,221
127.0	20,676	151.0	25,493	175.0	29,926	199.0	33,665	223.0	36,258
127.5	20,779	151.5	25,590	175.5	30,012	199.5	33,732	223.5	36,294
128.0	20,881	152.0	25,687	176.0	30,098	200.0	33,800	224.0	36,328
128.5	20,983	152.5	25,784	176.5	30,183	200.5	33,866	224.5	36,362
129.0	21,086	153.0	25,881	177.0	30,269	201.0	33,933	225.0	36,395
129.5	21,188	153.5	25,977	177.5	30,354	201.5	33,998	225.5	36,427
130.0	21,290	154.0	26,074	178.0	30,438	202.0	34,064	226.0	36,457
130.5	21,392	154.5	26,170	178.5	30,522	202.5	34,128	226.5	36,487
131.0	21,494	155.0	26,266	179.0	30,606	203.0	34,193	227.0	36,515
131.5	21,596	155.5	26,362	179.5	30,690	203.5	34,256	227.5	36,541
132.0	21,698	156.0	26,457	180.0	30,774	204.0	34,320	228.0	36,567
132.5	21,800	156.5	26,553	180.5	30,857	204.5	34,382	228.5	36,591
133.0	21,901	157.0	26,648	181.0	30,939	205.0	34,444	229.0	36,613
133.5	22,003	157.5	26,743	181.5	31,022	205.5	34,506	229.5	36,634
134.0	22,105	158.0	26,838	182.0	31,104	206.0	34,567	230.0	36,652
134.5	22,206	158.5	26,933	182.5	31,185	206.5	34,628	230.5	36,669
135.0	22,308	159.0	27,027	183.0	31,267	207.0	34,688	231.0	36,684
135.5	22,409	159.5	27,121	183.5	31,348	207.5	34,747	231.5	36,695
136.0	22,510	160.0	27,215	184.0	31,428	208.0	34,806	232.0	36,703
136.5	22,611	160.5	27,309	184.5	31,509	208.5	34,864		
137.0	22,712	161.0	27,403	185.0	31,589	209.0	34,922		
137.5	22,813	161.5	27,496	185.5	31,668	209.5	34,979		
138.0	22,914	162.0	27,589	186.0	31,747	210.0	35,035		
138.5	23,015	162.5	27,682	186.5	31,826	210.5	35,091		
139.0	23,115	163.0	27,775	187.0	31,905	211.0	35,146		
139.5	23,216	163.5	27,868	187.5	31,983	211.5	35,201		
140.0	23,316	164.0	27,960	188.0	32,060	212.0	35,254		
140.5	23,417	164.5	28,052	188.5	32,138	212.5	35,308		
141.0	23,517	165.0	28,144	189.0	32,214	213.0	35,360		
141.5	23,617	165.5	28,235	189.5	32,291	213.5	35,412		
142.0	23,717	166.0	28,327	190.0	32,367	214.0	35,464		
142.5	23,817	166.5	28,418	190.5	32,443	214.5	35,514		
143.0	23,916	167.0	28,508	191.0	32,518	215.0	35,564		
143.5	24,016	167.5	28,599	191.5	32,593	215.5	35,613		
144.0	24,115	168.0	28,689	192.0	32,668	216.0	35,662		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.