

DWT6 8'-12000 COMPARTMENT
43,892 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	29	24.5	2,434	48.5	6,520	72.5	11,560	96.5	17,158
1.0	47	25.0	2,506	49.0	6,617	73.0	11,672	97.0	17,278
1.5	67	25.5	2,578	49.5	6,714	73.5	11,784	97.5	17,398
2.0	90	26.0	2,651	50.0	6,812	74.0	11,897	98.0	17,519
2.5	116	26.5	2,725	50.5	6,910	74.5	12,010	98.5	17,639
3.0	143	27.0	2,800	51.0	7,008	75.0	12,123	99.0	17,760
3.5	172	27.5	2,875	51.5	7,107	75.5	12,236	99.5	17,881
4.0	203	28.0	2,951	52.0	7,206	76.0	12,349	100.0	18,001
4.5	235	28.5	3,027	52.5	7,306	76.5	12,463	100.5	18,122
5.0	269	29.0	3,104	53.0	7,406	77.0	12,577	101.0	18,243
5.5	305	29.5	3,181	53.5	7,506	77.5	12,691	101.5	18,364
6.0	342	30.0	3,259	54.0	7,607	78.0	12,806	102.0	18,485
6.5	380	30.5	3,338	54.5	7,708	78.5	12,920	102.5	18,607
7.0	420	31.0	3,418	55.0	7,809	79.0	13,035	103.0	18,728
7.5	461	31.5	3,497	55.5	7,911	79.5	13,150	103.5	18,849
8.0	503	32.0	3,578	56.0	8,013	80.0	13,265	104.0	18,971
8.5	546	32.5	3,659	56.5	8,116	80.5	13,380	104.5	19,092
9.0	591	33.0	3,741	57.0	8,219	81.0	13,496	105.0	19,214
9.5	636	33.5	3,823	57.5	8,322	81.5	13,612	105.5	19,335
10.0	683	34.0	3,905	58.0	8,425	82.0	13,728	106.0	19,457
10.5	731	34.5	3,989	58.5	8,529	82.5	13,844	106.5	19,578
11.0	780	35.0	4,072	59.0	8,634	83.0	13,960	107.0	19,700
11.5	830	35.5	4,157	59.5	8,738	83.5	14,076	107.5	19,822
12.0	881	36.0	4,242	60.0	8,843	84.0	14,193	108.0	19,944
12.5	933	36.5	4,327	60.5	8,948	84.5	14,310	108.5	20,066
13.0	986	37.0	4,413	61.0	9,054	85.0	14,427	109.0	20,188
13.5	1,040	37.5	4,499	61.5	9,159	85.5	14,544	109.5	20,309
14.0	1,094	38.0	4,586	62.0	9,265	86.0	14,661	110.0	20,431
14.5	1,150	38.5	4,674	62.5	9,372	86.5	14,779	110.5	20,553
15.0	1,207	39.0	4,761	63.0	9,479	87.0	14,896	111.0	20,676
15.5	1,264	39.5	4,850	63.5	9,586	87.5	15,014	111.5	20,798
16.0	1,322	40.0	4,939	64.0	9,693	88.0	15,132	112.0	20,920
16.5	1,382	40.5	5,028	64.5	9,801	88.5	15,250	112.5	21,042
17.0	1,442	41.0	5,118	65.0	9,908	89.0	15,368	113.0	21,164
17.5	1,502	41.5	5,208	65.5	10,017	89.5	15,487	113.5	21,286
18.0	1,564	42.0	5,299	66.0	10,125	90.0	15,605	114.0	21,408
18.5	1,627	42.5	5,390	66.5	10,234	90.5	15,724	114.5	21,530
19.0	1,690	43.0	5,482	67.0	10,343	91.0	15,843	115.0	21,653
19.5	1,754	43.5	5,574	67.5	10,452	91.5	15,962	115.5	21,775
20.0	1,819	44.0	5,667	68.0	10,562	92.0	16,081	116.0	21,897
20.5	1,884	44.5	5,760	68.5	10,672	92.5	16,200	116.5	22,019
21.0	1,950	45.0	5,853	69.0	10,782	93.0	16,319	117.0	22,141
21.5	2,017	45.5	5,947	69.5	10,892	93.5	16,439	117.5	22,264
22.0	2,085	46.0	6,042	70.0	11,003	94.0	16,558	118.0	22,386
22.5	2,153	46.5	6,136	70.5	11,114	94.5	16,678	118.5	22,508
23.0	2,222	47.0	6,232	71.0	11,225	95.0	16,798	119.0	22,630
23.5	2,292	47.5	6,327	71.5	11,336	95.5	16,918	119.5	22,752
24.0	2,363	48.0	6,423	72.0	11,448	96.0	17,038	120.0	22,874

DWT6 8'-1200 COMPARTMENT
43,892 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	22,997	144.5	28,783	168.5	34,221	192.5	38,972	216.5	42,583
121.0	23,119	145.0	28,901	169.0	34,328	193.0	39,061	217.0	42,641
121.5	23,241	145.5	29,019	169.5	34,435	193.5	39,149	217.5	42,698
122.0	23,363	146.0	29,137	170.0	34,542	194.0	39,237	218.0	42,755
122.5	23,485	146.5	29,254	170.5	34,648	194.5	39,324	218.5	42,810
123.0	23,607	147.0	29,372	171.0	34,754	195.0	39,411	219.0	42,865
123.5	23,729	147.5	29,489	171.5	34,860	195.5	39,497	219.5	42,919
124.0	23,851	148.0	29,606	172.0	34,965	196.0	39,583	220.0	42,971
124.5	23,973	148.5	29,722	172.5	35,070	196.5	39,668	220.5	43,023
125.0	24,094	149.0	29,839	173.0	35,175	197.0	39,753	221.0	43,074
125.5	24,216	149.5	29,955	173.5	35,280	197.5	39,837	221.5	43,124
126.0	24,338	150.0	30,072	174.0	35,384	198.0	39,921	222.0	43,172
126.5	24,460	150.5	30,188	174.5	35,488	198.5	40,004	222.5	43,220
127.0	24,581	151.0	30,304	175.0	35,591	199.0	40,087	223.0	43,267
127.5	24,703	151.5	30,419	175.5	35,694	199.5	40,169	223.5	43,312
128.0	24,824	152.0	30,535	176.0	35,797	200.0	40,250	224.0	43,356
128.5	24,946	152.5	30,650	176.5	35,899	200.5	40,331	224.5	43,400
129.0	25,067	153.0	30,765	177.0	36,002	201.0	40,412	225.0	43,442
129.5	25,188	153.5	30,880	177.5	36,103	201.5	40,491	225.5	43,482
130.0	25,310	154.0	30,995	178.0	36,205	202.0	40,571	226.0	43,522
130.5	25,431	154.5	31,109	178.5	36,306	202.5	40,649	226.5	43,560
131.0	25,552	155.0	31,224	179.0	36,406	203.0	40,727	227.0	43,597
131.5	25,673	155.5	31,338	179.5	36,507	203.5	40,805	227.5	43,632
132.0	25,794	156.0	31,452	180.0	36,607	204.0	40,881	228.0	43,666
132.5	25,915	156.5	31,565	180.5	36,706	204.5	40,958	228.5	43,698
133.0	26,035	157.0	31,679	181.0	36,805	205.0	41,033	229.0	43,728
133.5	26,156	157.5	31,792	181.5	36,904	205.5	41,108	229.5	43,757
134.0	26,277	158.0	31,905	182.0	37,002	206.0	41,183	230.0	43,784
134.5	26,397	158.5	32,018	182.5	37,100	206.5	41,256	230.5	43,809
135.0	26,518	159.0	32,130	183.0	37,198	207.0	41,329	231.0	43,831
135.5	26,638	159.5	32,243	183.5	37,295	207.5	41,402	231.5	43,852
136.0	26,758	160.0	32,355	184.0	37,392	208.0	41,473	232.0	43,869
136.5	26,878	160.5	32,467	184.5	37,488	208.5	41,545	232.5	43,883
137.0	26,998	161.0	32,578	185.0	37,584	209.0	41,615	233.0	43,892
137.5	27,118	161.5	32,690	185.5	37,680	209.5	41,685		
138.0	27,238	162.0	32,801	186.0	37,775	210.0	41,754		
138.5	27,358	162.5	32,912	186.5	37,870	210.5	41,822		
139.0	27,477	163.0	33,022	187.0	37,964	211.0	41,889		
139.5	27,597	163.5	33,132	187.5	38,058	211.5	41,956		
140.0	27,716	164.0	33,243	188.0	38,151	212.0	42,022		
140.5	27,835	164.5	33,352	188.5	38,244	212.5	42,088		
141.0	27,954	165.0	33,462	189.0	38,337	213.0	42,152		
141.5	28,073	165.5	33,571	189.5	38,429	213.5	42,216		
142.0	28,192	166.0	33,680	190.0	38,521	214.0	42,279		
142.5	28,310	166.5	33,789	190.5	38,612	214.5	42,342		
143.0	28,429	167.0	33,897	191.0	38,703	215.0	42,403		
143.5	28,547	167.5	34,005	191.5	38,793	215.5	42,464		
144.0	28,665	168.0	34,113	192.0	38,883	216.0	42,524		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.