

DWT6 10'-12000 COMPARTMENT
44,942 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.6	18	31.1	2,130	61.6	6,042	92.1	11,055	122.6	16,746
1.3	31	31.8	2,197	62.2	6,137	92.7	11,168	123.2	16,869
1.9	46	32.4	2,264	62.9	6,232	93.3	11,281	123.8	16,992
2.5	64	33.0	2,332	63.5	6,328	94.0	11,395	124.5	17,116
3.2	83	33.7	2,401	64.1	6,424	94.6	11,509	125.1	17,239
3.8	105	34.3	2,471	64.8	6,521	95.3	11,623	125.7	17,363
4.4	128	34.9	2,541	65.4	6,618	95.9	11,737	126.4	17,487
5.1	153	35.6	2,612	66.0	6,716	96.5	11,852	127.0	17,611
5.7	179	36.2	2,683	66.7	6,814	97.2	11,967	127.6	17,735
6.3	206	36.8	2,756	67.3	6,912	97.8	12,082	128.3	17,859
7.0	236	37.5	2,829	67.9	7,011	98.4	12,197	128.9	17,983
7.6	266	38.1	2,902	68.6	7,111	99.1	12,313	129.5	18,108
8.3	298	38.7	2,976	69.2	7,211	99.7	12,429	130.2	18,232
8.9	331	39.4	3,051	69.8	7,311	100.3	12,545	130.8	18,357
9.5	365	40.0	3,127	70.5	7,411	101.0	12,662	131.4	18,481
10.2	401	40.6	3,203	71.1	7,512	101.6	12,778	132.1	18,606
10.8	438	41.3	3,280	71.8	7,614	102.2	12,895	132.7	18,731
11.4	475	41.9	3,357	72.4	7,716	102.9	13,012	133.3	18,856
12.1	515	42.5	3,436	73.0	7,818	103.5	13,130	134.0	18,981
12.7	555	43.2	3,514	73.7	7,921	104.1	13,248	134.6	19,106
13.3	596	43.8	3,594	74.3	8,024	104.8	13,365	135.3	19,231
14.0	638	44.5	3,674	74.9	8,127	105.4	13,484	135.9	19,356
14.6	682	45.1	3,754	75.6	8,231	106.0	13,602	136.5	19,482
15.2	726	45.7	3,835	76.2	8,335	106.7	13,720	137.2	19,607
15.9	771	46.4	3,917	76.8	8,440	107.3	13,839	137.8	19,733
16.5	818	47.0	3,999	77.5	8,545	107.9	13,958	138.4	19,858
17.1	865	47.6	4,082	78.1	8,650	108.6	14,077	139.1	19,984
17.8	914	48.3	4,166	78.7	8,756	109.2	14,197	139.7	20,109
18.4	963	48.9	4,250	79.4	8,862	109.9	14,316	140.3	20,235
19.0	1,013	49.5	4,334	80.0	8,969	110.5	14,436	141.0	20,361
19.7	1,064	50.2	4,419	80.6	9,075	111.1	14,556	141.6	20,487
20.3	1,116	50.8	4,505	81.3	9,183	111.8	14,676	142.2	20,613
21.0	1,169	51.4	4,591	81.9	9,290	112.4	14,797	142.9	20,739
21.6	1,223	52.1	4,678	82.5	9,398	113.0	14,917	143.5	20,865
22.2	1,278	52.7	4,765	83.2	9,506	113.7	15,038	144.1	20,991
22.9	1,333	53.3	4,853	83.8	9,615	114.3	15,159	144.8	21,117
23.5	1,390	54.0	4,942	84.5	9,724	114.9	15,280	145.4	21,243
24.1	1,447	54.6	5,031	85.1	9,833	115.6	15,401	146.1	21,369
24.8	1,505	55.2	5,120	85.7	9,942	116.2	15,523	146.7	21,495
25.4	1,564	55.9	5,210	86.4	10,052	116.8	15,644	147.3	21,621
26.0	1,624	56.5	5,300	87.0	10,162	117.5	15,766	148.0	21,747
26.7	1,685	57.1	5,391	87.6	10,273	118.1	15,888	148.6	21,873
27.3	1,746	57.8	5,483	88.3	10,384	118.7	16,010	149.2	22,000
27.9	1,808	58.4	5,575	88.9	10,495	119.4	16,132	149.9	22,126
28.6	1,871	59.1	5,667	89.5	10,606	120.0	16,255	150.5	22,252
29.2	1,935	59.7	5,760	90.2	10,718	120.7	16,377	151.1	22,378
29.8	1,999	60.3	5,854	90.8	10,830	121.3	16,500	151.8	22,504
30.5	2,064	61.0	5,948	91.4	10,943	121.9	16,623	152.4	22,631

DWT6 10'-12000 COMPARTMENT
44,942 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
153.0	22,757	183.5	28,752	214.0	34,395	244.5	39,325	275.0	43,107
153.7	22,883	184.1	28,875	214.6	34,507	245.1	39,417	275.6	43,169
154.3	23,009	184.8	28,997	215.3	34,618	245.7	39,509	276.2	43,231
154.9	23,136	185.4	29,119	215.9	34,728	246.4	39,600	276.9	43,292
155.6	23,262	186.1	29,241	216.5	34,839	247.0	39,691	277.5	43,352
156.2	23,388	186.7	29,362	217.2	34,949	247.6	39,781	278.1	43,411
156.8	23,514	187.3	29,484	217.8	35,058	248.3	39,871	278.8	43,470
157.5	23,640	188.0	29,605	218.4	35,168	248.9	39,960	279.4	43,527
158.1	23,766	188.6	29,727	219.1	35,277	249.6	40,048	280.0	43,584
158.8	23,892	189.2	29,848	219.7	35,386	250.2	40,137	280.7	43,640
159.4	24,018	189.9	29,968	220.3	35,494	250.8	40,224	281.3	43,695
160.0	24,144	190.5	30,089	221.0	35,602	251.5	40,311	281.9	43,750
160.7	24,270	191.1	30,209	221.6	35,710	252.1	40,398	282.6	43,803
161.3	24,396	191.8	30,330	222.3	35,817	252.7	40,484	283.2	43,856
161.9	24,522	192.4	30,450	222.9	35,924	253.4	40,569	283.8	43,907
162.6	24,648	193.0	30,570	223.5	36,031	254.0	40,654	284.5	43,958
163.2	24,774	193.7	30,689	224.2	36,137	254.6	40,738	285.1	44,008
163.8	24,899	194.3	30,809	224.8	36,243	255.3	40,822	285.8	44,057
164.5	25,025	194.9	30,928	225.4	36,348	255.9	40,905	286.4	44,104
165.1	25,150	195.6	31,047	226.1	36,453	256.5	40,988	287.0	44,151
165.7	25,276	196.2	31,166	226.7	36,558	257.2	41,070	287.7	44,197
166.4	25,401	196.8	31,285	227.3	36,663	257.8	41,151	288.3	44,242
167.0	25,527	197.5	31,403	228.0	36,767	258.4	41,232	288.9	44,286
167.6	25,652	198.1	31,521	228.6	36,870	259.1	41,312	289.6	44,329
168.3	25,777	198.8	31,639	229.2	36,974	259.7	41,392	290.2	44,371
168.9	25,902	199.4	31,757	229.9	37,077	260.4	41,471	290.8	44,411
169.5	26,028	200.0	31,875	230.5	37,179	261.0	41,549	291.5	44,451
170.2	26,153	200.7	31,992	231.1	37,281	261.6	41,627	292.1	44,489
170.8	26,277	201.3	32,109	231.8	37,383	262.3	41,704	292.7	44,527
171.4	26,402	201.9	32,226	232.4	37,484	262.9	41,781	293.4	44,563
172.1	26,527	202.6	32,342	233.0	37,585	263.5	41,857	294.0	44,598
172.7	26,652	203.2	32,459	233.7	37,685	264.2	41,932	294.6	44,632
173.4	26,776	203.8	32,575	234.3	37,785	264.8	42,007	295.3	44,664
174.0	26,900	204.5	32,691	234.9	37,885	265.4	42,081	295.9	44,695
174.6	27,025	205.1	32,806	235.6	37,984	266.1	42,154	296.5	44,725
175.3	27,149	205.7	32,922	236.2	38,083	266.7	42,227	297.2	44,753
175.9	27,273	206.4	33,037	236.9	38,181	267.3	42,298	297.8	44,780
176.5	27,397	207.0	33,151	237.5	38,279	268.0	42,370	298.4	44,806
177.2	27,521	207.6	33,266	238.1	38,376	268.6	42,440	299.1	44,830
177.8	27,645	208.3	33,380	238.8	38,473	269.2	42,510	299.7	44,852
178.4	27,768	208.9	33,494	239.4	38,570	269.9	42,579	300.4	44,872
179.1	27,892	209.6	33,608	240.0	38,666	270.5	42,648	301.0	44,891
179.7	28,015	210.2	33,721	240.7	38,761	271.1	42,716	301.6	44,908
180.3	28,138	210.8	33,834	241.3	38,856	271.8	42,783	302.3	44,922
181.0	28,261	211.5	33,947	241.9	38,951	272.4	42,849	302.9	44,934
181.6	28,384	212.1	34,059	242.6	39,045	273.0	42,914	303.5	44,942
182.2	28,507	212.7	34,172	243.2	39,139	273.7	42,979		
182.9	28,630	213.4	34,284	243.8	39,232	274.3	43,043		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.