

DWT6 10'-15000 COMPARTMENT
57,175 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	21	24.5	1,962	48.5	5,474	72.5	9,986	96.5	15,196
1.0	34	25.0	2,022	49.0	5,559	73.0	10,089	97.0	15,310
1.5	50	25.5	2,083	49.5	5,644	73.5	10,191	97.5	15,424
2.0	67	26.0	2,145	50.0	5,730	74.0	10,294	98.0	15,539
2.5	86	26.5	2,207	50.5	5,817	74.5	10,397	98.5	15,654
3.0	106	27.0	2,269	51.0	5,903	75.0	10,501	99.0	15,768
3.5	128	27.5	2,333	51.5	5,990	75.5	10,605	99.5	15,884
4.0	152	28.0	2,396	52.0	6,078	76.0	10,709	100.0	15,999
4.5	177	28.5	2,461	52.5	6,166	76.5	10,813	100.5	16,114
5.0	203	29.0	2,526	53.0	6,254	77.0	10,918	101.0	16,230
5.5	231	29.5	2,592	53.5	6,343	77.5	11,022	101.5	16,346
6.0	259	30.0	2,658	54.0	6,432	78.0	11,128	102.0	16,462
6.5	289	30.5	2,725	54.5	6,522	78.5	11,233	102.5	16,578
7.0	320	31.0	2,792	55.0	6,612	79.0	11,339	103.0	16,695
7.5	352	31.5	2,860	55.5	6,702	79.5	11,445	103.5	16,811
8.0	385	32.0	2,928	56.0	6,793	80.0	11,551	104.0	16,928
8.5	419	32.5	2,997	56.5	6,884	80.5	11,658	104.5	17,045
9.0	455	33.0	3,067	57.0	6,975	81.0	11,765	105.0	17,162
9.5	491	33.5	3,137	57.5	7,067	81.5	11,872	105.5	17,280
10.0	528	34.0	3,208	58.0	7,160	82.0	11,979	106.0	17,397
10.5	566	34.5	3,279	58.5	7,252	82.5	12,087	106.5	17,515
11.0	605	35.0	3,351	59.0	7,345	83.0	12,194	107.0	17,632
11.5	645	35.5	3,423	59.5	7,439	83.5	12,303	107.5	17,750
12.0	686	36.0	3,496	60.0	7,532	84.0	12,411	108.0	17,868
12.5	728	36.5	3,569	60.5	7,626	84.5	12,519	108.5	17,987
13.0	770	37.0	3,643	61.0	7,721	85.0	12,628	109.0	18,105
13.5	814	37.5	3,717	61.5	7,816	85.5	12,737	109.5	18,223
14.0	858	38.0	3,792	62.0	7,911	86.0	12,847	110.0	18,342
14.5	903	38.5	3,867	62.5	8,006	86.5	12,956	110.5	18,461
15.0	949	39.0	3,943	63.0	8,102	87.0	13,066	111.0	18,580
15.5	996	39.5	4,019	63.5	8,198	87.5	13,176	111.5	18,699
16.0	1,043	40.0	4,096	64.0	8,295	88.0	13,287	112.0	18,818
16.5	1,091	40.5	4,174	64.5	8,392	88.5	13,397	112.5	18,938
17.0	1,141	41.0	4,251	65.0	8,489	89.0	13,508	113.0	19,057
17.5	1,190	41.5	4,330	65.5	8,586	89.5	13,619	113.5	19,177
18.0	1,241	42.0	4,408	66.0	8,684	90.0	13,730	114.0	19,297
18.5	1,292	42.5	4,488	66.5	8,783	90.5	13,841	114.5	19,417
19.0	1,344	43.0	4,567	67.0	8,881	91.0	13,953	115.0	19,537
19.5	1,397	43.5	4,647	67.5	8,980	91.5	14,065	115.5	19,657
20.0	1,450	44.0	4,728	68.0	9,079	92.0	14,177	116.0	19,777
20.5	1,505	44.5	4,809	68.5	9,179	92.5	14,289	116.5	19,898
21.0	1,559	45.0	4,891	69.0	9,279	93.0	14,402	117.0	20,019
21.5	1,615	45.5	4,973	69.5	9,379	93.5	14,515	117.5	20,139
22.0	1,671	46.0	5,055	70.0	9,479	94.0	14,628	118.0	20,260
22.5	1,728	46.5	5,138	70.5	9,580	94.5	14,741	118.5	20,381
23.0	1,786	47.0	5,221	71.0	9,681	95.0	14,854	119.0	20,502
23.5	1,844	47.5	5,305	71.5	9,782	95.5	14,968	119.5	20,623
24.0	1,903	48.0	5,389	72.0	9,884	96.0	15,082	120.0	20,745

DWT6 10'-15000 COMPARTMENT
57,175 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	20,866	144.5	26,790	168.5	32,771	192.5	38,618
121.0	20,987	145.0	26,914	169.0	32,895	193.0	38,736
121.5	21,109	145.5	27,039	169.5	33,019	193.5	38,855
122.0	21,231	146.0	27,164	170.0	33,143	194.0	38,974
122.5	21,353	146.5	27,289	170.5	33,266	194.5	39,092
123.0	21,475	147.0	27,413	171.0	33,390	195.0	39,211
123.5	21,597	147.5	27,538	171.5	33,513	195.5	39,329
124.0	21,719	148.0	27,663	172.0	33,637	196.0	39,447
124.5	21,841	148.5	27,788	172.5	33,760	196.5	39,565
125.0	21,963	149.0	27,913	173.0	33,884	197.0	39,683
125.5	22,086	149.5	28,037	173.5	34,007	197.5	39,800
126.0	22,208	150.0	28,162	174.0	34,130	198.0	39,918
126.5	22,331	150.5	28,287	174.5	34,253	198.5	40,035
127.0	22,454	151.0	28,412	175.0	34,376	199.0	40,152
127.5	22,576	151.5	28,537	175.5	34,499	199.5	40,269
128.0	22,699	152.0	28,662	176.0	34,622	200.0	40,386
128.5	22,822	152.5	28,787	176.5	34,745	200.5	40,502
129.0	22,945	153.0	28,911	177.0	34,867	201.0	40,619
129.5	23,068	153.5	29,036	177.5	34,990	201.5	40,735
130.0	23,191	154.0	29,161	178.0	35,112	202.0	40,851
130.5	23,315	154.5	29,286	178.5	35,235	202.5	40,967
131.0	23,438	155.0	29,411	179.0	35,357	203.0	41,082
131.5	23,562	155.5	29,536	179.5	35,479	203.5	41,198
132.0	23,685	156.0	29,660	180.0	35,601	204.0	41,313
132.5	23,809	156.5	29,785	180.5	35,723	204.5	41,428
133.0	23,932	157.0	29,910	181.0	35,845	205.0	41,543
133.5	24,056	157.5	30,035	181.5	35,967	205.5	41,658
134.0	24,180	158.0	30,159	182.0	36,089	206.0	41,773
134.5	24,303	158.5	30,284	182.5	36,210	206.5	41,887
135.0	24,427	159.0	30,409	183.0	36,332	207.0	42,001
135.5	24,551	159.5	30,534	183.5	36,453	207.5	42,115
136.0	24,675	160.0	30,658	184.0	36,575	208.0	42,229
136.5	24,799	160.5	30,783	184.5	36,696	208.5	42,342
137.0	24,923	161.0	30,907	185.0	36,817	209.0	42,456
137.5	25,047	161.5	31,032	185.5	36,938	209.5	42,569
138.0	25,172	162.0	31,156	186.0	37,059	210.0	42,682
138.5	25,296	162.5	31,281	186.5	37,179	210.5	42,794
139.0	25,420	163.0	31,405	187.0	37,300	211.0	42,907
139.5	25,544	163.5	31,530	187.5	37,420	211.5	43,019
140.0	25,669	164.0	31,654	188.0	37,541	212.0	43,131
140.5	25,793	164.5	31,778	188.5	37,661	212.5	43,243
141.0	25,918	165.0	31,903	189.0	37,781	213.0	43,355
141.5	26,042	165.5	32,027	189.5	37,901	213.5	43,466
142.0	26,167	166.0	32,151	190.0	38,021	214.0	43,577
142.5	26,291	166.5	32,275	190.5	38,140	214.5	43,688
143.0	26,416	167.0	32,399	191.0	38,260	215.0	43,799
143.5	26,540	167.5	32,523	191.5	38,379	215.5	43,909
144.0	26,665	168.0	32,647	192.0	38,498	216.0	44,020

DWT6 10'-15000 COMPARTMENT
57,175 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	44,130	240.5	49,091	264.5	53,247	288.5	56,236
217.0	44,240	241.0	49,187	265.0	53,323	289.0	56,282
217.5	44,349	241.5	49,283	265.5	53,398	289.5	56,327
218.0	44,458	242.0	49,378	266.0	53,473	290.0	56,371
218.5	44,567	242.5	49,472	266.5	53,547	290.5	56,414
219.0	44,676	243.0	49,567	267.0	53,621	291.0	56,456
219.5	44,785	243.5	49,661	267.5	53,694	291.5	56,498
220.0	44,893	244.0	49,755	268.0	53,766	292.0	56,539
220.5	45,001	244.5	49,848	268.5	53,839	292.5	56,579
221.0	45,109	245.0	49,941	269.0	53,910	293.0	56,617
221.5	45,217	245.5	50,033	269.5	53,981	293.5	56,655
222.0	45,324	246.0	50,125	270.0	54,052	294.0	56,692
222.5	45,431	246.5	50,217	270.5	54,122	294.5	56,728
223.0	45,538	247.0	50,309	271.0	54,191	295.0	56,763
223.5	45,644	247.5	50,400	271.5	54,260	295.5	56,797
224.0	45,750	248.0	50,490	272.0	54,329	296.0	56,830
224.5	45,856	248.5	50,581	272.5	54,397	296.5	56,862
225.0	45,962	249.0	50,671	273.0	54,464	297.0	56,893
225.5	46,067	249.5	50,760	273.5	54,531	297.5	56,923
226.0	46,173	250.0	50,849	274.0	54,597	298.0	56,951
226.5	46,277	250.5	50,938	274.5	54,662	298.5	56,978
227.0	46,382	251.0	51,026	275.0	54,727	299.0	57,004
227.5	46,486	251.5	51,114	275.5	54,791	299.5	57,029
228.0	46,590	252.0	51,201	276.0	54,855	300.0	57,052
228.5	46,694	252.5	51,289	276.5	54,918	300.5	57,074
229.0	46,798	253.0	51,375	277.0	54,981	301.0	57,094
229.5	46,901	253.5	51,461	277.5	55,043	301.5	57,113
230.0	47,004	254.0	51,547	278.0	55,104	302.0	57,130
230.5	47,106	254.5	51,633	278.5	55,165	302.5	57,145
231.0	47,208	255.0	51,718	279.0	55,225	303.0	57,158
231.5	47,310	255.5	51,802	279.5	55,284	303.5	57,168
232.0	47,412	256.0	51,886	280.0	55,343	304.0	57,175
232.5	47,513	256.5	51,970	280.5	55,401		
233.0	47,614	257.0	52,053	281.0	55,459		
233.5	47,715	257.5	52,136	281.5	55,515		
234.0	47,816	258.0	52,218	282.0	55,571		
234.5	47,916	258.5	52,300	282.5	55,627		
235.0	48,015	259.0	52,382	283.0	55,682		
235.5	48,115	259.5	52,463	283.5	55,736		
236.0	48,214	260.0	52,543	284.0	55,789		
236.5	48,313	260.5	52,623	284.5	55,842		
237.0	48,411	261.0	52,703	285.0	55,894		
237.5	48,509	261.5	52,782	285.5	55,945		
238.0	48,607	262.0	52,861	286.0	55,995		
238.5	48,705	262.5	52,939	286.5	56,045		
239.0	48,802	263.0	53,017	287.0	56,094		
239.5	48,899	263.5	53,094	287.5	56,142		
240.0	48,995	264.0	53,171	288.0	56,189		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.