

DWT6 10'-16000 COMPARTMENT
60,233 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	22	24.5	2,083	48.5	5,793	72.5	10,549	96.5	16,032
1.0	37	25.0	2,146	49.0	5,883	73.0	10,657	97.0	16,152
1.5	53	25.5	2,211	49.5	5,973	73.5	10,765	97.5	16,272
2.0	71	26.0	2,276	50.0	6,063	74.0	10,873	98.0	16,393
2.5	92	26.5	2,341	50.5	6,155	74.5	10,982	98.5	16,514
3.0	114	27.0	2,408	51.0	6,246	75.0	11,091	99.0	16,635
3.5	137	27.5	2,475	51.5	6,338	75.5	11,200	99.5	16,756
4.0	162	28.0	2,542	52.0	6,430	76.0	11,310	100.0	16,877
4.5	189	28.5	2,610	52.5	6,523	76.5	11,420	100.5	16,998
5.0	217	29.0	2,679	53.0	6,616	77.0	11,530	101.0	17,120
5.5	246	29.5	2,748	53.5	6,710	77.5	11,640	101.5	17,242
6.0	276	30.0	2,818	54.0	6,804	78.0	11,751	102.0	17,364
6.5	308	30.5	2,889	54.5	6,898	78.5	11,862	102.5	17,486
7.0	341	31.0	2,960	55.0	6,993	79.0	11,973	103.0	17,609
7.5	375	31.5	3,032	55.5	7,088	79.5	12,085	103.5	17,731
8.0	410	32.0	3,105	56.0	7,184	80.0	12,197	104.0	17,854
8.5	447	32.5	3,178	56.5	7,280	80.5	12,309	104.5	17,977
9.0	484	33.0	3,251	57.0	7,377	81.0	12,422	105.0	18,100
9.5	523	33.5	3,325	57.5	7,474	81.5	12,534	105.5	18,224
10.0	562	34.0	3,400	58.0	7,571	82.0	12,647	106.0	18,347
10.5	602	34.5	3,475	58.5	7,668	82.5	12,761	106.5	18,471
11.0	644	35.0	3,551	59.0	7,766	83.0	12,874	107.0	18,595
11.5	686	35.5	3,627	59.5	7,865	83.5	12,988	107.5	18,719
12.0	730	36.0	3,704	60.0	7,964	84.0	13,102	108.0	18,843
12.5	774	36.5	3,782	60.5	8,063	84.5	13,216	108.5	18,967
13.0	819	37.0	3,860	61.0	8,162	85.0	13,331	109.0	19,092
13.5	865	37.5	3,938	61.5	8,262	85.5	13,446	109.5	19,216
14.0	912	38.0	4,017	62.0	8,363	86.0	13,561	110.0	19,341
14.5	960	38.5	4,097	62.5	8,463	86.5	13,676	110.5	19,466
15.0	1,009	39.0	4,177	63.0	8,564	87.0	13,792	111.0	19,591
15.5	1,058	39.5	4,258	63.5	8,666	87.5	13,907	111.5	19,716
16.0	1,109	40.0	4,339	64.0	8,767	88.0	14,023	112.0	19,842
16.5	1,160	40.5	4,420	64.5	8,869	88.5	14,140	112.5	19,967
17.0	1,212	41.0	4,503	65.0	8,972	89.0	14,256	113.0	20,093
17.5	1,265	41.5	4,585	65.5	9,075	89.5	14,373	113.5	20,219
18.0	1,318	42.0	4,668	66.0	9,178	90.0	14,490	114.0	20,345
18.5	1,373	42.5	4,752	66.5	9,281	90.5	14,607	114.5	20,471
19.0	1,428	43.0	4,836	67.0	9,385	91.0	14,725	115.0	20,597
19.5	1,484	43.5	4,921	67.5	9,489	91.5	14,843	115.5	20,724
20.0	1,541	44.0	5,006	68.0	9,594	92.0	14,960	116.0	20,850
20.5	1,598	44.5	5,091	68.5	9,699	92.5	15,079	116.5	20,977
21.0	1,656	45.0	5,178	69.0	9,804	93.0	15,197	117.0	21,104
21.5	1,715	45.5	5,264	69.5	9,909	93.5	15,316	117.5	21,231
22.0	1,774	46.0	5,351	70.0	10,015	94.0	15,435	118.0	21,358
22.5	1,835	46.5	5,439	70.5	10,121	94.5	15,554	118.5	21,485
23.0	1,896	47.0	5,526	71.0	10,228	95.0	15,673	119.0	21,612
23.5	1,957	47.5	5,615	71.5	10,335	95.5	15,792	119.5	21,739
24.0	2,020	48.0	5,704	72.0	10,442	96.0	15,912	120.0	21,867

DWT6 10'-16000 COMPARTMENT
60,233 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	21,995	144.5	28,221	168.5	34,507	192.5	40,652
121.0	22,122	145.0	28,352	169.0	34,637	193.0	40,777
121.5	22,250	145.5	28,483	169.5	34,767	193.5	40,902
122.0	22,378	146.0	28,614	170.0	34,897	194.0	41,027
122.5	22,506	146.5	28,745	170.5	35,027	194.5	41,152
123.0	22,634	147.0	28,876	171.0	35,157	195.0	41,276
123.5	22,763	147.5	29,007	171.5	35,287	195.5	41,400
124.0	22,891	148.0	29,138	172.0	35,416	196.0	41,525
124.5	23,019	148.5	29,269	172.5	35,546	196.5	41,648
125.0	23,148	149.0	29,401	173.0	35,676	197.0	41,772
125.5	23,277	149.5	29,532	173.5	35,805	197.5	41,896
126.0	23,406	150.0	29,663	174.0	35,935	198.0	42,019
126.5	23,534	150.5	29,794	174.5	36,064	198.5	42,143
127.0	23,663	151.0	29,925	175.0	36,193	199.0	42,266
127.5	23,792	151.5	30,057	175.5	36,323	199.5	42,389
128.0	23,922	152.0	30,188	176.0	36,452	200.0	42,512
128.5	24,051	152.5	30,319	176.5	36,581	200.5	42,634
129.0	24,180	153.0	30,450	177.0	36,710	201.0	42,757
129.5	24,309	153.5	30,581	177.5	36,839	201.5	42,879
130.0	24,439	154.0	30,713	178.0	36,967	202.0	43,001
130.5	24,569	154.5	30,844	178.5	37,096	202.5	43,123
131.0	24,698	155.0	30,975	179.0	37,225	203.0	43,244
131.5	24,828	155.5	31,106	179.5	37,353	203.5	43,366
132.0	24,958	156.0	31,237	180.0	37,481	204.0	43,487
132.5	25,087	156.5	31,369	180.5	37,610	204.5	43,608
133.0	25,217	157.0	31,500	181.0	37,738	205.0	43,729
133.5	25,347	157.5	31,631	181.5	37,866	205.5	43,850
134.0	25,477	158.0	31,762	182.0	37,994	206.0	43,970
134.5	25,608	158.5	31,893	182.5	38,122	206.5	44,091
135.0	25,738	159.0	32,024	183.0	38,249	207.0	44,211
135.5	25,868	159.5	32,155	183.5	38,377	207.5	44,330
136.0	25,998	160.0	32,286	184.0	38,504	208.0	44,450
136.5	26,129	160.5	32,417	184.5	38,632	208.5	44,570
137.0	26,259	161.0	32,548	185.0	38,759	209.0	44,689
137.5	26,389	161.5	32,679	185.5	38,886	209.5	44,808
138.0	26,520	162.0	32,810	186.0	39,013	210.0	44,927
138.5	26,651	162.5	32,940	186.5	39,140	210.5	45,045
139.0	26,781	163.0	33,071	187.0	39,267	211.0	45,164
139.5	26,912	163.5	33,202	187.5	39,393	211.5	45,282
140.0	27,043	164.0	33,333	188.0	39,520	212.0	45,400
140.5	27,173	164.5	33,463	188.5	39,646	212.5	45,517
141.0	27,304	165.0	33,594	189.0	39,773	213.0	45,635
141.5	27,435	165.5	33,724	189.5	39,899	213.5	45,752
142.0	27,566	166.0	33,855	190.0	40,025	214.0	45,869
142.5	27,697	166.5	33,985	190.5	40,150	214.5	45,986
143.0	27,828	167.0	34,116	191.0	40,276	215.0	46,102
143.5	27,959	167.5	34,246	191.5	40,402	215.5	46,218
144.0	28,090	168.0	34,376	192.0	40,527	216.0	46,334

DWT6 10'-16000 COMPARTMENT
60,233 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	46,450	240.5	51,675	264.5	56,059	288.5	59,221
217.0	46,566	241.0	51,776	265.0	56,139	289.0	59,270
217.5	46,681	241.5	51,877	265.5	56,218	289.5	59,317
218.0	46,796	242.0	51,977	266.0	56,297	290.0	59,364
218.5	46,911	242.5	52,077	266.5	56,376	290.5	59,410
219.0	47,025	243.0	52,176	267.0	56,453	291.0	59,455
219.5	47,140	243.5	52,275	267.5	56,531	291.5	59,499
220.0	47,254	244.0	52,374	268.0	56,608	292.0	59,543
220.5	47,367	244.5	52,472	268.5	56,684	292.5	59,585
221.0	47,481	245.0	52,570	269.0	56,760	293.0	59,626
221.5	47,594	245.5	52,668	269.5	56,835	293.5	59,667
222.0	47,707	246.0	52,765	270.0	56,909	294.0	59,706
222.5	47,820	246.5	52,862	270.5	56,983	294.5	59,744
223.0	47,932	247.0	52,958	271.0	57,057	295.0	59,781
223.5	48,044	247.5	53,054	271.5	57,130	295.5	59,817
224.0	48,156	248.0	53,150	272.0	57,202	296.0	59,852
224.5	48,268	248.5	53,245	272.5	57,274	296.5	59,886
225.0	48,379	249.0	53,340	273.0	57,345	297.0	59,919
225.5	48,490	249.5	53,434	273.5	57,415	297.5	59,951
226.0	48,601	250.0	53,528	274.0	57,485	298.0	59,981
226.5	48,711	250.5	53,622	274.5	57,555	298.5	60,010
227.0	48,821	251.0	53,715	275.0	57,623	299.0	60,038
227.5	48,931	251.5	53,807	275.5	57,691	299.5	60,064
228.0	49,040	252.0	53,900	276.0	57,759	300.0	60,089
228.5	49,150	252.5	53,992	276.5	57,826	300.5	60,112
229.0	49,259	253.0	54,083	277.0	57,892	301.0	60,134
229.5	49,367	253.5	54,174	277.5	57,957	301.5	60,154
230.0	49,475	254.0	54,264	278.0	58,022	302.0	60,172
230.5	49,584	254.5	54,355	278.5	58,086	302.5	60,188
231.0	49,691	255.0	54,444	279.0	58,150	303.0	60,201
231.5	49,799	255.5	54,533	279.5	58,213	303.5	60,212
232.0	49,906	256.0	54,622	280.0	58,275	304.0	60,233
232.5	50,012	256.5	54,711	280.5	58,337		
233.0	50,119	257.0	54,798	281.0	58,397		
233.5	50,225	257.5	54,886	281.5	58,458		
234.0	50,331	258.0	54,973	282.0	58,517		
234.5	50,436	258.5	55,059	282.5	58,576		
235.0	50,541	259.0	55,145	283.0	58,634		
235.5	50,646	259.5	55,231	283.5	58,691		
236.0	50,750	260.0	55,316	284.0	58,747		
236.5	50,855	260.5	55,400	284.5	58,803		
237.0	50,958	261.0	55,484	285.0	58,858		
237.5	51,062	261.5	55,568	285.5	58,912		
238.0	51,165	262.0	55,651	286.0	58,966		
238.5	51,268	262.5	55,733	286.5	59,019		
239.0	51,370	263.0	55,815	287.0	59,070		
239.5	51,472	263.5	55,897	287.5	59,122		
240.0	51,574	264.0	55,978	288.0	59,172		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.