

DWT6 10'-2200 COMPARTMENT
81,640 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.5	33	24.5	2,929	48.5	8,038	72.5	14,510	96.5	21,916
1.0	53	25.0	3,018	49.0	8,160	73.0	14,656	97.0	22,078
1.5	77	25.5	3,107	49.5	8,284	73.5	14,802	97.5	22,240
2.0	103	26.0	3,197	50.0	8,408	74.0	14,949	98.0	22,402
2.5	132	26.5	3,288	50.5	8,532	74.5	15,096	98.5	22,565
3.0	164	27.0	3,380	51.0	8,657	75.0	15,244	99.0	22,728
3.5	198	27.5	3,473	51.5	8,783	75.5	15,392	99.5	22,891
4.0	234	28.0	3,567	52.0	8,909	76.0	15,540	100.0	23,054
4.5	272	28.5	3,661	52.5	9,035	76.5	15,689	100.5	23,218
5.0	311	29.0	3,756	53.0	9,163	77.0	15,838	101.0	23,382
5.5	353	29.5	3,852	53.5	9,290	77.5	15,987	101.5	23,546
6.0	396	30.0	3,949	54.0	9,419	78.0	16,137	102.0	23,710
6.5	442	30.5	4,047	54.5	9,548	78.5	16,287	102.5	23,875
7.0	488	31.0	4,145	55.0	9,677	79.0	16,438	103.0	24,039
7.5	537	31.5	4,245	55.5	9,807	79.5	16,589	103.5	24,204
8.0	587	32.0	4,345	56.0	9,937	80.0	16,740	104.0	24,370
8.5	638	32.5	4,445	56.5	10,068	80.5	16,892	104.5	24,535
9.0	691	33.0	4,547	57.0	10,200	81.0	17,044	105.0	24,701
9.5	746	33.5	4,649	57.5	10,332	81.5	17,196	105.5	24,867
10.0	802	34.0	4,752	58.0	10,464	82.0	17,349	106.0	25,033
10.5	859	34.5	4,856	58.5	10,597	82.5	17,502	106.5	25,199
11.0	917	35.0	4,960	59.0	10,731	83.0	17,655	107.0	25,366
11.5	977	35.5	5,066	59.5	10,864	83.5	17,809	107.5	25,533
12.0	1,038	36.0	5,172	60.0	10,999	84.0	17,963	108.0	25,699
12.5	1,101	36.5	5,278	60.5	11,134	84.5	18,118	108.5	25,867
13.0	1,164	37.0	5,386	61.0	11,269	85.0	18,272	109.0	26,034
13.5	1,229	37.5	5,494	61.5	11,405	85.5	18,427	109.5	26,202
14.0	1,295	38.0	5,603	62.0	11,542	86.0	18,583	110.0	26,369
14.5	1,362	38.5	5,712	62.5	11,678	86.5	18,739	110.5	26,537
15.0	1,431	39.0	5,822	63.0	11,816	87.0	18,895	111.0	26,706
15.5	1,500	39.5	5,933	63.5	11,954	87.5	19,051	111.5	26,874
16.0	1,571	40.0	6,044	64.0	12,092	88.0	19,208	112.0	27,043
16.5	1,643	40.5	6,157	64.5	12,231	88.5	19,365	112.5	27,211
17.0	1,716	41.0	6,269	65.0	12,370	89.0	19,522	113.0	27,380
17.5	1,789	41.5	6,383	65.5	12,509	89.5	19,679	113.5	27,549
18.0	1,864	42.0	6,497	66.0	12,649	90.0	19,837	114.0	27,719
18.5	1,940	42.5	6,612	66.5	12,790	90.5	19,995	114.5	27,888
19.0	2,017	43.0	6,727	67.0	12,931	91.0	20,154	115.0	28,058
19.5	2,096	43.5	6,843	67.5	13,072	91.5	20,313	115.5	28,227
20.0	2,175	44.0	6,960	68.0	13,214	92.0	20,472	116.0	28,397
20.5	2,255	44.5	7,077	68.5	13,356	92.5	20,631	116.5	28,568
21.0	2,336	45.0	7,195	69.0	13,499	93.0	20,791	117.0	28,738
21.5	2,418	45.5	7,314	69.5	13,642	93.5	20,951	117.5	28,908
22.0	2,501	46.0	7,433	70.0	13,786	94.0	21,111	118.0	29,079
22.5	2,584	46.5	7,553	70.5	13,930	94.5	21,271	118.5	29,250
23.0	2,669	47.0	7,673	71.0	14,074	95.0	21,432	119.0	29,421
23.5	2,755	47.5	7,794	71.5	14,219	95.5	21,593	119.5	29,592
24.0	2,842	48.0	7,916	72.0	14,364	96.0	21,754	120.0	29,763

DWT6 10'-22000 COMPARTMENT
81,640 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
120.5	29,934	144.5	38,287	168.5	46,716	192.5	54,967
121.0	30,106	145.0	38,463	169.0	46,891	193.0	55,135
121.5	30,278	145.5	38,639	169.5	47,065	193.5	55,303
122.0	30,449	146.0	38,814	170.0	47,240	194.0	55,471
122.5	30,621	146.5	38,990	170.5	47,414	194.5	55,639
123.0	30,793	147.0	39,166	171.0	47,588	195.0	55,806
123.5	30,966	147.5	39,342	171.5	47,763	195.5	55,973
124.0	31,138	148.0	39,518	172.0	47,937	196.0	56,140
124.5	31,310	148.5	39,694	172.5	48,111	196.5	56,307
125.0	31,483	149.0	39,869	173.0	48,285	197.0	56,473
125.5	31,656	149.5	40,045	173.5	48,458	197.5	56,640
126.0	31,829	150.0	40,221	174.0	48,632	198.0	56,806
126.5	32,001	150.5	40,397	174.5	48,806	198.5	56,972
127.0	32,175	151.0	40,573	175.0	48,979	199.0	57,137
127.5	32,348	151.5	40,749	175.5	49,153	199.5	57,303
128.0	32,521	152.0	40,925	176.0	49,326	200.0	57,468
128.5	32,694	152.5	41,101	176.5	49,499	200.5	57,633
129.0	32,868	153.0	41,277	177.0	49,672	201.0	57,798
129.5	33,042	153.5	41,453	177.5	49,845	201.5	57,962
130.0	33,215	154.0	41,629	178.0	50,018	202.0	58,126
130.5	33,389	154.5	41,805	178.5	50,191	202.5	58,290
131.0	33,563	155.0	41,980	179.0	50,363	203.0	58,454
131.5	33,737	155.5	42,156	179.5	50,536	203.5	58,618
132.0	33,911	156.0	42,332	180.0	50,708	204.0	58,781
132.5	34,085	156.5	42,508	180.5	50,880	204.5	58,944
133.0	34,260	157.0	42,684	181.0	51,052	205.0	59,107
133.5	34,434	157.5	42,860	181.5	51,224	205.5	59,269
134.0	34,608	158.0	43,035	182.0	51,396	206.0	59,432
134.5	34,783	158.5	43,211	182.5	51,567	206.5	59,594
135.0	34,958	159.0	43,387	183.0	51,739	207.0	59,756
135.5	35,132	159.5	43,562	183.5	51,910	207.5	59,917
136.0	35,307	160.0	43,738	184.0	52,081	208.0	60,078
136.5	35,482	160.5	43,914	184.5	52,253	208.5	60,239
137.0	35,657	161.0	44,089	185.0	52,423	209.0	60,400
137.5	35,832	161.5	44,265	185.5	52,594	209.5	60,560
138.0	36,007	162.0	44,440	186.0	52,765	210.0	60,721
138.5	36,182	162.5	44,616	186.5	52,935	210.5	60,880
139.0	36,357	163.0	44,791	187.0	53,106	211.0	61,040
139.5	36,532	163.5	44,966	187.5	53,276	211.5	61,199
140.0	36,708	164.0	45,142	188.0	53,446	212.0	61,358
140.5	36,883	164.5	45,317	188.5	53,615	212.5	61,517
141.0	37,058	165.0	45,492	189.0	53,785	213.0	61,675
141.5	37,234	165.5	45,667	189.5	53,954	213.5	61,834
142.0	37,409	166.0	45,842	190.0	54,124	214.0	61,991
142.5	37,585	166.5	46,017	190.5	54,293	214.5	62,149
143.0	37,760	167.0	46,192	191.0	54,462	215.0	62,306
143.5	37,936	167.5	46,367	191.5	54,630	215.5	62,463
144.0	38,112	168.0	46,542	192.0	54,799	216.0	62,620

DWT6 10'-22000 COMPARTMENT
81,640 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
216.5	62,776	240.5	69,852	264.5	75,840	288.5	80,225
217.0	62,932	241.0	69,989	265.0	75,950	289.0	80,293
217.5	63,088	241.5	70,126	265.5	76,060	289.5	80,360
218.0	63,243	242.0	70,262	266.0	76,168	290.0	80,426
218.5	63,398	242.5	70,398	266.5	76,276	290.5	80,490
219.0	63,553	243.0	70,533	267.0	76,384	291.0	80,554
219.5	63,707	243.5	70,668	267.5	76,490	291.5	80,616
220.0	63,861	244.0	70,802	268.0	76,596	292.0	80,677
220.5	64,015	244.5	70,936	268.5	76,701	292.5	80,736
221.0	64,168	245.0	71,070	269.0	76,806	293.0	80,795
221.5	64,321	245.5	71,202	269.5	76,909	293.5	80,852
222.0	64,474	246.0	71,335	270.0	77,012	294.0	80,907
222.5	64,626	246.5	71,467	270.5	77,114	294.5	80,961
223.0	64,778	247.0	71,598	271.0	77,216	295.0	81,014
223.5	64,930	247.5	71,729	271.5	77,316	295.5	81,065
224.0	65,081	248.0	71,859	272.0	77,416	296.0	81,115
224.5	65,232	248.5	71,989	272.5	77,515	296.5	81,163
225.0	65,382	249.0	72,118	273.0	77,614	297.0	81,210
225.5	65,532	249.5	72,247	273.5	77,711	297.5	81,254
226.0	65,682	250.0	72,375	274.0	77,808	298.0	81,298
226.5	65,832	250.5	72,503	274.5	77,904	298.5	81,339
227.0	65,981	251.0	72,630	275.0	77,999	299.0	81,379
227.5	66,129	251.5	72,757	275.5	78,093	299.5	81,416
228.0	66,278	252.0	72,883	276.0	78,187	300.0	81,452
228.5	66,425	252.5	73,008	276.5	78,279	300.5	81,485
229.0	66,573	253.0	73,133	277.0	78,371	301.0	81,516
229.5	66,720	253.5	73,257	277.5	78,462	301.5	81,545
230.0	66,867	254.0	73,381	278.0	78,552	302.0	81,571
230.5	67,013	254.5	73,504	278.5	78,641	302.5	81,594
231.0	67,159	255.0	73,627	279.0	78,729	303.0	81,614
231.5	67,305	255.5	73,749	279.5	78,817	303.5	81,630
232.0	67,450	256.0	73,870	280.0	78,903	304.0	81,640
232.5	67,594	256.5	73,991	280.5	78,989		
233.0	67,739	257.0	74,112	281.0	79,074		
233.5	67,883	257.5	74,231	281.5	79,157		
234.0	68,026	258.0	74,350	282.0	79,240		
234.5	68,169	258.5	74,469	282.5	79,322		
235.0	68,312	259.0	74,586	283.0	79,403		
235.5	68,454	259.5	74,704	283.5	79,483		
236.0	68,596	260.0	74,820	284.0	79,561		
236.5	68,737	260.5	74,936	284.5	79,639		
237.0	68,878	261.0	75,052	285.0	79,716		
237.5	69,018	261.5	75,166	285.5	79,792		
238.0	69,158	262.0	75,280	286.0	79,867		
238.5	69,298	262.5	75,394	286.5	79,941		
239.0	69,437	263.0	75,506	287.0	80,013		
239.5	69,576	263.5	75,618	287.5	80,085		
240.0	69,714	264.0	75,730	288.0	80,155		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.