## DWT6 4'-600 COMPARTMENT 2,294 Liters

DIPSTICK	VOLUME								
(cm)	(L)								
0.5	4	24.5	325	48.5	859	72.5	1,450	96.5	1,981
1.0	6	25.0	335	49.0	871	73.0	1,462	97.0	1,990
1.5	8	25.5	344	49.5	883	73.5	1,474	97.5	2,000
2.0	11	26.0	354	50.0	895	74.0	1,486	98.0	2,009
2.5	15	26.5	364	50.5	907	74.5	1,498	98.5	2,018
3.0	18	27.0	374	51.0	920	75.0	1,510	99.0	2,027
3.5	22	27.5	384	51.5	932	75.5	1,522	99.5	2,036
4.0	26	28.0	394	52.0	944	76.0	1,534	100.0	2,045
4.5	30	28.5	405	52.5	956	76.5	1,546	100.5	2,054
5.0	35	29.0	415	53.0	969	77.0	1,558	101.0	2,063
5.5	39	29.5	425	53.5	981	77.5	1,570	101.5	2,071
6.0	44	30.0	436	54.0	993	78.0	1,582	102.0	2,080
6.5	49	30.5	446	54.5	1,006	78.5	1,593	102.5	2,088
7.0	54	31.0	457	55.0	1,018	79.0	1,605	103.0	2,097
7.5	60	31.5	467	55.5	1,030	79.5	1,617	103.5	2,105
8.0	65	32.0	478	56.0	1,043	80.0	1,628	104.0	2,113
8.5	71	32.5	489	56.5	1,055	80.5	1,640	104.5	2,121
9.0	77	33.0	500	57.0	1,068	81.0	1,652	105.0	2,129
9.5	83	33.5	510	57.5	1,080	81.5	1,663	105.5	2,123
10.0	89	34.0	521	58.0	1,000	82.0	1,674	106.0	2,144
10.5	96	34.5	532	58.5	1,105	82.5	1,686	106.5	2,151
11.0	102	35.0	543	59.0	1,117	83.0	1,697	100.5	2,151
11.5	102	35.5	554	59.5	1,117	83.5	1,709	107.5	2,166
12.0	116	36.0	566	60.0	1,142	84.0	1,709	107.5	2,173
12.5	123	36.5	577	60.5	1,155	84.5	1,720	108.5	2,173
13.0	130	37.0	588	61.0	1,167	85.0	1,742	100.5	2,187
13.5	137	37.5	599	61.5	1,179	85.5	1,742	109.5	2,107
14.0	145	38.0	611	62.0	1,179	86.0	1,764	110.0	2,193
14.5	152	38.5	622	62.5	1,192	86.5	1,775	110.5	2,206
15.0	160	39.0	634	63.0	1,204	87.0	1,775	111.0	2,213
15.5	167	39.5	645	63.5	1,229	87.5	1,797	111.5	2,219
16.0	175	40.0	657	64.0	1,242	88.0	1,808	112.0	2,225
16.5	183	40.5	668	64.5	1,254	88.5	1,819	112.5	2,230
17.0	191	41.0	680	65.0	1,266	89.0	1,829	113.0	2,236
17.5	200	41.5	692	65.5	1,279	89.5	1,840	113.5	2,230
18.0	208	42.0	703	66.0	1,273	90.0	1,850	114.0	2,246
18.5	216	42.5	715	66.5	1,303	90.5	1,861	114.5	2,240
19.0	225	43.0	727	67.0	1,316	91.0	1,871	115.0	2,256
19.5	233	43.5	739	67.5	1,310	91.5	1,882	115.5	2,261
20.0	242	44.0	750	68.0	1,340	92.0	1,892	116.0	2,265
20.5	251	44.5	762	68.5	1,353	92.5	1,902	116.5	2,269
21.0	260	45.0	774	69.0	1,365	93.0	1,902	117.0	2,209
21.5	269	45.5	786	69.5	1,303	93.5	1,912	117.5	2,277
22.0	278	46.0	798	70.0	1,389	94.0	1,932	118.0	2,281
22.5	287	46.5	810	70.5	1,402	94.0	1,932	118.5	2,284
23.0	297	47.0	822	71.0	1,402	95.0	1,942	119.0	2,287
23.5	306	47.5	834	71.0	1,414	95.5	1,952	119.0	2,289
24.0	315	48.0	846	72.0	1,438	96.0	1,971	120.0	2,291





## DWT6 4'-600 COMPARTMENT 2,294 Liters

DIPSTICK	VOLUME	
(cm)	(L)	Fiber Glass Systems
120.5	2,293	Tibel Oldss Gystellis
121.0	2,294	
		HOW TO PROPERLY OALLOS VOLES TANK
		HOW TO PROPERLY GAUGE YOUR TANK: Underground storage tanks require periodic measurement to determine current inventory level. Using
		the proper methods when gauging your tank's contents will insure the most accurate reading and
		insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:
		1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will
		insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
		2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the
		gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping
		can also result in gauge stick damage and tank damage.  3) Remove your dipstick slowly and read the product level directly from the gauge stick.
		The move your dipolick slowly and road the product level directly from the gauge slick.
		Water Paste Detection
		To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze
		mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or
		antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:
		Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions 7915 East Elm Street
		Houston, TX 77012
		Phone (713) 926-4780 E-Mail Sales@KolorKut.com
		L-Iviali Gales@RolofRut.com
		Caution
		Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling
		the tank under pressure will damage the tank even if the tank vent is unrestricted.
		NOV - Fiber Glass Systems - Containment Solutions™ Tanks
		500 Conroe Park Drive West
		Conroe, TX 77303 Tel: 936-756-7731
		Fax: 936-756-7766
		Note: Calibration short is based on the fluid level above a 5/46" deflector plate
		Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.
		1
		1



