

Model DWT6 (8) 30000
DW FRP CUL Tank = 30,821 Liters

Liquid Depth (cm)	Volume (liters)	Liquid Depth (cm)	Volume (liters)	Liquid Depth (cm)	Volume (liters)	Liquid Depth (cm)	Volume (liters)	Liquid Depth (cm)	Volume (liters)
0.5	20	30.5	2,297	60.5	6,219	90.5	11,001	120.5	16,155
1.0	32	31.0	2,353	61.0	6,293	91.0	11,086	121.0	16,242
1.5	46	31.5	2,408	61.5	6,368	91.5	11,170	121.5	16,328
2.0	61	32.0	2,464	62.0	6,442	92.0	11,254	122.0	16,415
2.5	79	32.5	2,520	62.5	6,517	92.5	11,338	122.5	16,501
3.0	97	33.0	2,577	63.0	6,592	93.0	11,423	123.0	16,588
3.5	117	33.5	2,634	63.5	6,667	93.5	11,507	123.5	16,674
4.0	138	34.0	2,691	64.0	6,743	94.0	11,592	124.0	16,761
4.5	160	34.5	2,749	64.5	6,819	94.5	11,677	124.5	16,847
5.0	183	35.0	2,807	65.0	6,895	95.0	11,762	125.0	16,933
5.5	208	35.5	2,866	65.5	6,971	95.5	11,847	125.5	17,020
6.0	233	36.0	2,925	66.0	7,047	96.0	11,932	126.0	17,106
6.5	259	36.5	2,984	66.5	7,124	96.5	12,017	126.5	17,192
7.0	286	37.0	3,044	67.0	7,201	97.0	12,102	127.0	17,278
7.5	314	37.5	3,104	67.5	7,278	97.5	12,187	127.5	17,364
8.0	343	38.0	3,165	68.0	7,355	98.0	12,272	128.0	17,451
8.5	373	38.5	3,226	68.5	7,432	98.5	12,358	128.5	17,537
9.0	403	39.0	3,287	69.0	7,510	99.0	12,443	129.0	17,623
9.5	434	39.5	3,349	69.5	7,588	99.5	12,529	129.5	17,709
10.0	466	40.0	3,411	70.0	7,666	100.0	12,614	130.0	17,795
10.5	499	40.5	3,473	70.5	7,744	100.5	12,700	130.5	17,880
11.0	533	41.0	3,536	71.0	7,822	101.0	12,786	131.0	17,966
11.5	567	41.5	3,599	71.5	7,901	101.5	12,871	131.5	18,052
12.0	602	42.0	3,662	72.0	7,980	102.0	12,957	132.0	18,138
12.5	637	42.5	3,726	72.5	8,058	102.5	13,043	132.5	18,223
13.0	674	43.0	3,790	73.0	8,138	103.0	13,129	133.0	18,309
13.5	711	43.5	3,854	73.5	8,217	103.5	13,215	133.5	18,394
14.0	748	44.0	3,919	74.0	8,296	104.0	13,301	134.0	18,480
14.5	787	44.5	3,984	74.5	8,376	104.5	13,387	134.5	18,565
15.0	825	45.0	4,049	75.0	8,456	105.0	13,473	135.0	18,650
15.5	865	45.5	4,115	75.5	8,536	105.5	13,559	135.5	18,736
16.0	905	46.0	4,181	76.0	8,616	106.0	13,646	136.0	18,821
16.5	946	46.5	4,247	76.5	8,696	106.5	13,732	136.5	18,906
17.0	987	47.0	4,314	77.0	8,776	107.0	13,818	137.0	18,991
17.5	1,029	47.5	4,381	77.5	8,857	107.5	13,904	137.5	19,076
18.0	1,071	48.0	4,448	78.0	8,938	108.0	13,991	138.0	19,161
18.5	1,114	48.5	4,515	78.5	9,019	108.5	14,077	138.5	19,245
19.0	1,158	49.0	4,583	79.0	9,100	109.0	14,164	139.0	19,330
19.5	1,202	49.5	4,651	79.5	9,181	109.5	14,250	139.5	19,415
20.0	1,247	50.0	4,720	80.0	9,262	110.0	14,337	140.0	19,499
20.5	1,292	50.5	4,788	80.5	9,344	110.5	14,423	140.5	19,583
21.0	1,337	51.0	4,857	81.0	9,426	111.0	14,510	141.0	19,668
21.5	1,384	51.5	4,927	81.5	9,507	111.5	14,596	141.5	19,752
22.0	1,430	52.0	4,996	82.0	9,589	112.0	14,683	142.0	19,836
22.5	1,478	52.5	5,066	82.5	9,671	112.5	14,769	142.5	19,920
23.0	1,525	53.0	5,136	83.0	9,754	113.0	14,856	143.0	20,004
23.5	1,573	53.5	5,206	83.5	9,836	113.5	14,942	143.5	20,087
24.0	1,622	54.0	5,277	84.0	9,918	114.0	15,029	144.0	20,171
24.5	1,671	54.5	5,348	84.5	10,001	114.5	15,116	144.5	20,255
25.0	1,721	55.0	5,419	85.0	10,084	115.0	15,202	145.0	20,338
25.5	1,771	55.5	5,491	85.5	10,167	115.5	15,289	145.5	20,421
26.0	1,822	56.0	5,562	86.0	10,250	116.0	15,376	146.0	20,505
26.5	1,873	56.5	5,634	86.5	10,333	116.5	15,462	146.5	20,588
27.0	1,924	57.0	5,706	87.0	10,416	117.0	15,549	147.0	20,671
27.5	1,976	57.5	5,779	87.5	10,499	117.5	15,635	147.5	20,753
28.0	2,029	58.0	5,852	88.0	10,583	118.0	15,722	148.0	20,836
28.5	2,082	58.5	5,925	88.5	10,666	118.5	15,809	148.5	20,919
29.0	2,135	59.0	5,998	89.0	10,750	119.0	15,895	149.0	21,001
29.5	2,189	59.5	6,071	89.5	10,834	119.5	15,982	149.5	21,083
30.0	2,243	60.0	6,145	90.0	10,917	120.0	16,069	150.0	21,166

**Model DWT6 (8) 30000
DW FRP CUL Tank = 30,821 Liters**

Liquid Depth (cm)	Volume (liters)	Liquid Depth (cm)	Volume (liters)	Liquid Depth (cm)	Volume (liters)
150.5	21,248	180.5	25,839	210.5	29,401
151.0	21,330	181.0	25,908	211.0	29,447
151.5	21,411	181.5	25,977	211.5	29,493
152.0	21,493	182.0	26,046	212.0	29,539
152.5	21,574	182.5	26,115	212.5	29,584
153.0	21,656	183.0	26,183	213.0	29,628
153.5	21,737	183.5	26,251	213.5	29,672
154.0	21,818	184.0	26,319	214.0	29,716
154.5	21,899	184.5	26,387	214.5	29,759
155.0	21,980	185.0	26,454	215.0	29,801
155.5	22,060	185.5	26,521	215.5	29,843
156.0	22,141	186.0	26,587	216.0	29,884
156.5	22,221	186.5	26,653	216.5	29,925
157.0	22,301	187.0	26,719	217.0	29,965
157.5	22,381	187.5	26,785	217.5	30,004
158.0	22,461	188.0	26,850	218.0	30,043
158.5	22,540	188.5	26,915	218.5	30,081
159.0	22,620	189.0	26,980	219.0	30,118
159.5	22,699	189.5	27,044	219.5	30,155
160.0	22,778	190.0	27,108	220.0	30,191
160.5	22,857	190.5	27,172	220.5	30,227
161.0	22,936	191.0	27,235	221.0	30,262
161.5	23,014	191.5	27,298	221.5	30,296
162.0	23,092	192.0	27,361	222.0	30,329
162.5	23,171	192.5	27,423	222.5	30,362
163.0	23,249	193.0	27,485	223.0	30,394
163.5	23,326	193.5	27,546	223.5	30,425
164.0	23,404	194.0	27,607	224.0	30,455
164.5	23,481	194.5	27,668	224.5	30,485
165.0	23,558	195.0	27,729	225.0	30,514
165.5	23,635	195.5	27,789	225.5	30,541
166.0	23,712	196.0	27,849	226.0	30,568
166.5	23,789	196.5	27,908	226.5	30,594
167.0	23,865	197.0	27,967	227.0	30,619
167.5	23,941	197.5	28,025	227.5	30,643
168.0	24,017	198.0	28,084	228.0	30,667
168.5	24,093	198.5	28,141	228.5	30,688
169.0	24,168	199.0	28,199	229.0	30,709
169.5	24,244	199.5	28,256	229.5	30,729
170.0	24,319	200.0	28,312	230.0	30,747
170.5	24,394	200.5	28,369	230.5	30,764
171.0	24,468	201.0	28,424	231.0	30,779
171.5	24,542	201.5	28,480	231.5	30,793
172.0	24,617	202.0	28,535	232.0	30,805
172.5	24,690	202.5	28,589	232.5	30,814
173.0	24,764	203.0	28,643	233.0	30,821
173.5	24,838	203.5	28,697		
174.0	24,911	204.0	28,750		
174.5	24,984	204.5	28,803		
175.0	25,056	205.0	28,855		
175.5	25,129	205.5	28,907		
176.0	25,201	206.0	28,959		
176.5	25,273	206.5	29,010		
177.0	25,345	207.0	29,060		
177.5	25,416	207.5	29,110		
178.0	25,487	208.0	29,160		
178.5	25,558	208.5	29,209		
179.0	25,629	209.0	29,258		
179.5	25,699	209.5	29,306		
180.0	25,769	210.0	29,353		



CONTAINMENT SOLUTIONS®

HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection:

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. See vendor below or suitable equal.

Gasoila Water Finding Paste

Federal Process Corp.

800-846-7325

www.gasoila.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. **Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.**

Containment Solutions, Inc.

333 North Rivershire Dr., Suite 190

Conroe, TX 77304

Tel: 936-756-7731

Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 8mm [5/16"] deflector plate.

Pub No. CAL 8-3000LDWT=CAN 5/11