

DWT6 8'-6000 COMPARTMENT
22,321 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.6	16	31.1	1,674	61.6	4,572	92.1	8,141
1.3	27	31.8	1,725	62.2	4,641	92.7	8,220
1.9	41	32.4	1,776	62.9	4,711	93.3	8,298
2.5	56	33.0	1,827	63.5	4,780	94.0	8,377
3.2	73	33.7	1,879	64.1	4,850	94.6	8,456
3.8	91	34.3	1,931	64.8	4,920	95.3	8,535
4.4	110	34.9	1,984	65.4	4,990	95.9	8,614
5.1	131	35.6	2,038	66.0	5,061	96.5	8,693
5.7	153	36.2	2,091	66.7	5,132	97.2	8,773
6.3	176	36.8	2,146	67.3	5,203	97.8	8,852
7.0	200	37.5	2,200	67.9	5,274	98.4	8,932
7.6	225	38.1	2,256	68.6	5,346	99.1	9,011
8.3	251	38.7	2,311	69.2	5,418	99.7	9,091
8.9	278	39.4	2,367	69.8	5,490	100.3	9,171
9.5	306	40.0	2,424	70.5	5,563	101.0	9,251
10.2	334	40.6	2,481	71.1	5,635	101.6	9,331
10.8	364	41.3	2,538	71.8	5,708	102.2	9,411
11.4	394	41.9	2,596	72.4	5,781	102.9	9,491
12.1	426	42.5	2,654	73.0	5,854	103.5	9,571
12.7	458	43.2	2,713	73.7	5,928	104.1	9,651
13.3	491	43.8	2,772	74.3	6,002	104.8	9,731
14.0	524	44.5	2,831	74.9	6,076	105.4	9,811
14.6	558	45.1	2,891	75.6	6,150	106.0	9,892
15.2	594	45.7	2,951	76.2	6,224	106.7	9,972
15.9	629	46.4	3,012	76.8	6,299	107.3	10,053
16.5	666	47.0	3,073	77.5	6,373	107.9	10,133
17.1	703	47.6	3,134	78.1	6,448	108.6	10,214
17.8	741	48.3	3,196	78.7	6,524	109.2	10,294
18.4	779	48.9	3,258	79.4	6,599	109.9	10,375
19.0	818	49.5	3,321	80.0	6,675	110.5	10,456
19.7	858	50.2	3,383	80.6	6,750	111.1	10,536
20.3	899	50.8	3,447	81.3	6,826	111.8	10,617
21.0	940	51.4	3,510	81.9	6,902	112.4	10,698
21.6	981	52.1	3,574	82.5	6,979	113.0	10,778
22.2	1,024	52.7	3,638	83.2	7,055	113.7	10,859
22.9	1,066	53.3	3,703	83.8	7,132	114.3	10,940
23.5	1,110	54.0	3,768	84.5	7,208	114.9	11,021
24.1	1,154	54.6	3,833	85.1	7,285	115.6	11,102
24.8	1,198	55.2	3,899	85.7	7,362	116.2	11,182
25.4	1,244	55.9	3,965	86.4	7,440	116.8	11,263
26.0	1,289	56.5	4,031	87.0	7,517	117.5	11,344
26.7	1,336	57.1	4,098	87.6	7,594	118.1	11,425
27.3	1,382	57.8	4,165	88.3	7,672	118.7	11,505
27.9	1,430	58.4	4,232	88.9	7,750	119.4	11,586
28.6	1,478	59.1	4,299	89.5	7,828	120.0	11,667
29.2	1,526	59.7	4,367	90.2	7,906	120.7	11,748
29.8	1,575	60.3	4,435	90.8	7,984	121.3	11,828
30.5	1,624	61.0	4,504	91.4	8,062	121.9	11,909

DWT6 8'-6000 COMPARTMENT
22,321 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
122.6	11,990	153.0	15,763	183.5	19,097	214.0	21,564
123.2	12,070	153.7	15,838	184.1	19,159	214.6	21,602
123.8	12,151	154.3	15,913	184.8	19,221	215.3	21,640
124.5	12,231	154.9	15,988	185.4	19,282	215.9	21,677
125.1	12,312	155.6	16,063	186.1	19,343	216.5	21,713
125.7	12,392	156.2	16,137	186.7	19,403	217.2	21,748
126.4	12,473	156.8	16,212	187.3	19,463	217.8	21,783
127.0	12,553	157.5	16,286	188.0	19,523	218.4	21,817
127.6	12,633	158.1	16,360	188.6	19,582	219.1	21,850
128.3	12,713	158.8	16,433	189.2	19,641	219.7	21,883
128.9	12,794	159.4	16,507	189.9	19,699	220.3	21,914
129.5	12,874	160.0	16,580	190.5	19,757	221.0	21,945
130.2	12,954	160.7	16,653	191.1	19,815	221.6	21,975
130.8	13,034	161.3	16,725	191.8	19,872	222.3	22,004
131.4	13,114	161.9	16,798	192.4	19,929	222.9	22,033
132.1	13,193	162.6	16,870	193.0	19,985	223.5	22,060
132.7	13,273	163.2	16,942	193.7	20,041	224.2	22,087
133.3	13,353	163.8	17,014	194.3	20,096	224.8	22,112
134.0	13,432	164.5	17,086	194.9	20,151	225.4	22,137
134.6	13,512	165.1	17,157	195.6	20,206	226.1	22,160
135.3	13,591	165.7	17,228	196.2	20,260	226.7	22,183
135.9	13,671	166.4	17,299	196.8	20,313	227.3	22,204
136.5	13,750	167.0	17,369	197.5	20,367	228.0	22,224
137.2	13,829	167.6	17,439	198.1	20,419	228.6	22,243
137.8	13,908	168.3	17,509	198.8	20,471	229.2	22,260
138.4	13,987	168.9	17,579	199.4	20,523	229.9	22,276
139.1	14,065	169.5	17,648	200.0	20,574	230.5	22,291
139.7	14,144	170.2	17,718	200.7	20,625	231.1	22,303
140.3	14,223	170.8	17,786	201.3	20,675	231.8	22,313
141.0	14,301	171.4	17,855	201.9	20,725	232.4	22,321
141.6	14,379	172.1	17,923	202.6	20,774		
142.2	14,457	172.7	17,991	203.2	20,823		
142.9	14,535	173.4	18,059	203.8	20,871		
143.5	14,613	174.0	18,126	204.5	20,918		
144.1	14,691	174.6	18,193	205.1	20,965		
144.8	14,769	175.3	18,260	205.7	21,012		
145.4	14,846	175.9	18,326	206.4	21,058		
146.1	14,923	176.5	18,392	207.0	21,103		
146.7	15,001	177.2	18,458	207.6	21,148		
147.3	15,078	177.8	18,524	208.3	21,192		
148.0	15,154	178.4	18,589	208.9	21,236		
148.6	15,231	179.1	18,654	209.6	21,279		
149.2	15,308	179.7	18,718	210.2	21,322		
149.9	15,384	180.3	18,782	210.8	21,364		
150.5	15,460	181.0	18,846	211.5	21,405		
151.1	15,536	181.6	18,909	212.1	21,446		
151.8	15,612	182.2	18,972	212.7	21,486		
152.4	15,688	182.9	19,035	213.4	21,525		

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.