

DWT6 8'-8000 COMPARTMENT
29,507 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
0.6	22	31.1	2,264	61.6	6,114	92.1	10,803	122.6	15,838
1.3	37	31.8	2,332	62.2	6,205	92.7	10,906	123.2	15,944
1.9	56	32.4	2,400	62.9	6,296	93.3	11,009	123.8	16,049
2.5	77	33.0	2,469	63.5	6,388	94.0	11,112	124.5	16,154
3.2	99	33.7	2,538	64.1	6,480	94.6	11,215	125.1	16,260
3.8	124	34.3	2,608	64.8	6,572	95.3	11,319	125.7	16,365
4.4	151	34.9	2,679	65.4	6,665	95.9	11,422	126.4	16,470
5.1	179	35.6	2,750	66.0	6,758	96.5	11,526	127.0	16,575
5.7	209	36.2	2,822	66.7	6,851	97.2	11,630	127.6	16,680
6.3	240	36.8	2,895	67.3	6,945	97.8	11,734	128.3	16,785
7.0	273	37.5	2,968	67.9	7,039	98.4	11,838	128.9	16,890
7.6	307	38.1	3,041	68.6	7,133	99.1	11,942	129.5	16,995
8.3	343	38.7	3,116	69.2	7,228	99.7	12,046	130.2	17,099
8.9	379	39.4	3,190	69.8	7,323	100.3	12,151	130.8	17,204
9.5	417	40.0	3,266	70.5	7,418	101.0	12,255	131.4	17,309
10.2	456	40.6	3,342	71.1	7,514	101.6	12,360	132.1	17,413
10.8	497	41.3	3,418	71.8	7,610	102.2	12,465	132.7	17,517
11.4	538	41.9	3,495	72.4	7,706	102.9	12,569	133.3	17,622
12.1	581	42.5	3,572	73.0	7,802	103.5	12,674	134.0	17,726
12.7	624	43.2	3,650	73.7	7,899	104.1	12,779	134.6	17,830
13.3	669	43.8	3,729	74.3	7,996	104.8	12,884	135.3	17,934
14.0	714	44.5	3,808	74.9	8,093	105.4	12,989	135.9	18,038
14.6	761	45.1	3,888	75.6	8,190	106.0	13,094	136.5	18,141
15.2	808	45.7	3,968	76.2	8,288	106.7	13,200	137.2	18,245
15.9	857	46.4	4,048	76.8	8,386	107.3	13,305	137.8	18,348
16.5	906	47.0	4,129	77.5	8,484	107.9	13,410	138.4	18,452
17.1	956	47.6	4,211	78.1	8,583	108.6	13,516	139.1	18,555
17.8	1,008	48.3	4,293	78.7	8,682	109.2	13,621	139.7	18,658
18.4	1,060	48.9	4,375	79.4	8,781	109.9	13,726	140.3	18,761
19.0	1,113	49.5	4,458	80.0	8,880	110.5	13,832	141.0	18,863
19.7	1,166	50.2	4,541	80.6	8,979	111.1	13,937	141.6	18,966
20.3	1,221	50.8	4,625	81.3	9,079	111.8	14,043	142.2	19,068
21.0	1,276	51.4	4,709	81.9	9,179	112.4	14,149	142.9	19,171
21.6	1,332	52.1	4,794	82.5	9,279	113.0	14,254	143.5	19,273
22.2	1,389	52.7	4,879	83.2	9,379	113.7	14,360	144.1	19,374
22.9	1,447	53.3	4,965	83.8	9,479	114.3	14,465	144.8	19,476
23.5	1,506	54.0	5,051	84.5	9,580	114.9	14,571	145.4	19,578
24.1	1,565	54.6	5,137	85.1	9,681	115.6	14,677	146.1	19,679
24.8	1,625	55.2	5,224	85.7	9,782	116.2	14,782	146.7	19,780
25.4	1,686	55.9	5,311	86.4	9,883	116.8	14,888	147.3	19,881
26.0	1,747	56.5	5,399	87.0	9,985	117.5	14,994	148.0	19,982
26.7	1,810	57.1	5,487	87.6	10,086	118.1	15,099	148.6	20,083
27.3	1,872	57.8	5,575	88.3	10,188	118.7	15,205	149.2	20,183
27.9	1,936	58.4	5,664	88.9	10,290	119.4	15,310	149.9	20,283
28.6	2,000	59.1	5,753	89.5	10,392	120.0	15,416	150.5	20,383
29.2	2,065	59.7	5,843	90.2	10,495	120.7	15,522	151.1	20,483
29.8	2,131	60.3	5,933	90.8	10,597	121.3	15,627	151.8	20,582
30.5	2,197	61.0	6,023	91.4	10,700	121.9	15,733	152.4	20,682

DWT6 8'-8000 COMPARTMENT
29,507 Liters

06/22/2023

DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)	DIPSTICK (cm)	VOLUME (L)
153.0	20,781	183.5	25,178	214.0	28,478	192.5		216.5	
153.7	20,880	184.1	25,260	214.6	28,530	193.0		217.0	
154.3	20,978	184.8	25,342	215.3	28,581	193.5		217.5	
154.9	21,076	185.4	25,423	215.9	28,630	194.0		218.0	
155.6	21,175	186.1	25,504	216.5	28,679	194.5		218.5	
156.2	21,272	186.7	25,584	217.2	28,727	195.0		219.0	
156.8	21,370	187.3	25,664	217.8	28,774	195.5		219.5	
157.5	21,467	188.0	25,743	218.4	28,820	196.0		220.0	
158.1	21,564	188.6	25,822	219.1	28,866	196.5		220.5	
158.8	21,661	189.2	25,900	219.7	28,910	197.0		221.0	
159.4	21,758	189.9	25,978	220.3	28,953	197.5		221.5	
160.0	21,854	190.5	26,055	221.0	28,995	198.0		222.0	
160.7	21,950	191.1	26,132	221.6	29,035	198.5		222.5	
161.3	22,046	191.8	26,208	222.3	29,075	199.0		223.0	
161.9	22,141	192.4	26,284	222.9	29,114	199.5		223.5	
162.6	22,236	193.0	26,359	223.5	29,151	200.0		224.0	
163.2	22,331	193.7	26,433	224.2	29,187	200.5		224.5	
163.8	22,426	194.3	26,507	224.8	29,222	201.0		225.0	
164.5	22,520	194.9	26,581	225.4	29,255	201.5		225.5	
165.1	22,614	195.6	26,653	226.1	29,287	202.0		226.0	
165.7	22,707	196.2	26,726	226.7	29,318	202.5		226.5	
166.4	22,800	196.8	26,797	227.3	29,347	203.0		227.0	
167.0	22,893	197.5	26,868	228.0	29,374	203.5		227.5	
167.6	22,986	198.1	26,939	228.6	29,400	204.0		228.0	
168.3	23,078	198.8	27,008	229.2	29,424	204.5		228.5	
168.9	23,170	199.4	27,078	229.9	29,446	205.0		229.0	
169.5	23,262	200.0	27,146	230.5	29,465	205.5		229.5	
170.2	23,353	200.7	27,214	231.1	29,483	206.0		230.0	
170.8	23,444	201.3	27,281	231.8	29,497	206.5		230.5	
171.4	23,534	201.9	27,348	232.4	29,507	207.0		231.0	
172.1	23,624	202.6	27,414			207.5		231.5	
172.7	23,714	203.2	27,479			208.0		232.0	
173.4	23,803	203.8	27,544			208.5		232.5	
174.0	23,892	204.5	27,608			209.0		233.0	
174.6	23,981	205.1	27,671			209.5			
175.3	24,069	205.7	27,733			210.0			
175.9	24,157	206.4	27,795			210.5			
176.5	24,244	207.0	27,856			211.0			
177.2	24,331	207.6	27,917			211.5			
177.8	24,418	208.3	27,976			212.0			
178.4	24,504	208.9	28,035			212.5			
179.1	24,590	209.6	28,094			213.0			
179.7	24,675	210.2	28,151			213.5			
180.3	24,760	210.8	28,207			214.0			
181.0	24,845	211.5	28,263			214.5			
181.6	24,929	212.1	28,318			215.0			
182.2	25,012	212.7	28,372			215.5			
182.9	25,095	213.4	28,426			216.0			

Fiber Glass Systems



HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

Kolor Kut Water Finding Paste Description - PASTE02 - for Salt and Chloride Solutions
7915 East Elm Street
Houston, TX 77012
Phone (713) 926-4780
E-Mail Sales@KolorKut.com

Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.

NOV - Fiber Glass Systems - Containment Solutions™ Tanks

500 Conroe Park Drive West
Conroe, TX 77303
Tel: 936-756-7731
Fax: 936-756-7766

Note: Calibration chart is based on the fluid level above a 5/16" deflector plate.