

## 4'-600 SWT D5 Single-Wall Tank 606 Gals

DIPSTICK	GALLONS	DIPSTICK	GALLONS	DIPSTICK	GALLONS	DIPSTICK	GALLONS	DIPSTICK	GALLONS
1/8	1	6 1/8	44	12 1/8	120	18 1/8	211	24 1/8	310
1/4	1	6 1/4	46	12 1/4	121	18 1/4	213	24 1/4	312
3/8	1	6 3/8	47	12 3/8	123	18 3/8	215	24 3/8	314
1/2	2	6 1/2	48	12 1/2	125	18 1/2	217	24 1/2	317
5/8	2	6 5/8	50	12 5/8	127	18 5/8	219	24 5/8	319
3/4	3	6 3/4	51	12 3/4	129	18 3/4	221	24 3/4	321
7/8	3	6 7/8	53	12 7/8	130	18 7/8	223	24 7/8	323
1	4	7	54	13	132	19	225	25	325
1 1/8	5	7 1/8	55	13 1/8	134	19 1/8	227	25 1/8	327
1 1/4	5	7 1/4	57	13 1/4	136	19 1/4	230	25 1/4	329
1 3/8	6	7 3/8	58	13 3/8	138	19 3/8	232	25 3/8	331
1 1/2	6	7 1/2	60	13 1/2	140	19 1/2	234	25 1/2	333
1 5/8	7	7 5/8	61	13 5/8	141	19 5/8	236	25 5/8	335
1 3/4	8	7 3/4	63	13 3/4	143	19 3/4	238	25 3/4	337
1 7/8	9	7 7/8	64	13 7/8	145	19 7/8	240	25 7/8	339
2	9	8	66	14	147	20	242	26	342
2 1/8	10	8 1/8	67	14 1/8	149	20 1/8	244	26 1/8	344
2 1/4	11	8 1/4	69	14 1/4	151	20 1/4	246	26 1/4	346
2 3/8	12	8 3/8	70	14 3/8	153	20 3/8	248	26 3/8	348
2 1/2	13	8 1/2	72	14 1/2	154	20 1/2	250	26 1/2	350
2 5/8	13	8 5/8	73	14 5/8	156	20 5/8	252	26 5/8	352
2 3/4	14	8 3/4	75	14 3/4	158	20 3/4	254	26 3/4	354
2 7/8	15	8 7/8	76	14 7/8	160	20 7/8	256	26 7/8	356
3	16	9	78	15	162	21	258	27	358
3 1/8	17	9 1/8	79	15 1/8	164	21 1/8	260	27 1/8	360
3 1/4	18	9 1/4	81	15 1/4	166	21 1/4	262	27 1/4	362
3 3/8	19	9 3/8	82	15 3/8	168	21 3/8	265	27 3/8	364
3 1/2	20	9 1/2	84	15 1/2	170	21 1/2	267	27 1/2	366
3 5/8	21	9 5/8	86	15 5/8	172	21 5/8	269	27 5/8	368
3 3/4	22	9 3/4	87	15 3/4	174	21 3/4	271	27 3/4	370
3 7/8	23	9 7/8	89	15 7/8	176	21 7/8	273	27 7/8	372
4	24	10	91	16	178	22	275	28	374
4 1/8	25	10 1/8	92	16 1/8	179	22 1/8	277	28 1/8	377
4 1/4	26	10 1/4	94	16 1/4	181	22 1/4	279	28 1/4	379
4 3/8	27	10 3/8	96	16 3/8	183	22 3/8	281	28 3/8	381
4 1/2	29	10 1/2	97	16 1/2	185	22 1/2	283	28 1/2	383
4 5/8	30	10 5/8	99	16 5/8	187	22 5/8	285	28 5/8	385
4 3/4	31	10 3/4	101	16 3/4	189	22 3/4	287	28 3/4	387
4 7/8	32	10 7/8	102	16 7/8	191	22 7/8	289	28 7/8	389
5	33	11	104	17	193	23	292	29	391
5 1/8	34	11 1/8	106	17 1/8	195	23 1/8	294	29 1/8	393
5 1/4	36	11 1/4	107	17 1/4	197	23 1/4	296	29 1/4	395
5 3/8	37	11 3/8	109	17 3/8	199	23 3/8	298	29 3/8	397
5 1/2	38	11 1/2	111	17 1/2	201	23 1/2	300	29 1/2	399
5 5/8	39	11 5/8	113	17 5/8	203	23 5/8	302	29 5/8	401
5 3/4	41	11 3/4	114	17 3/4	205	23 3/4	304	29 3/4	403
5 7/8	42	11 7/8	116	17 7/8	207	23 7/8	306	29 7/8	405
6	43	12	118	18	209	24	308	30	407

## 4'-600 SWT D5 Single-Wall Tank 606 Gals

DIPSTICK	GALLONS	DIPSTICK	GALLONS	DIPSTICK	GALLONS
30 1/8	409	36 1/8	499	42 1/8	570
30 1/4	411	36 1/4	500	42 1/4	572
30 3/8	413	36 3/8	502	42 3/8	573
30 1/2	415	36 1/2	504	42 1/2	574
30 5/8	417	36 5/8	505	42 5/8	575
30 3/4	419	36 3/4	507	42 3/4	576
30 7/8	421	36 7/8	509	42 7/8	577
31	423	37	511	43	579
31 1/8	425	37 1/8	512	43 1/8	580
31 1/4	427	37 1/4	514	43 1/4	581
31 3/8	429	37 3/8	515	43 3/8	582
31 1/2	430	37 1/2	517	43 1/2	583
31 5/8	432	37 5/8	519	43 5/8	584
31 3/4	434	37 3/4	520	43 3/4	585
31 7/8	436	37 7/8	522	43 7/8	586
32	438	38	524	44	587
32 1/8	440	38 1/8	525	44 1/8	588
32 1/4	442	38 1/4	527	44 1/4	589
32 3/8	444	38 3/8	528	44 3/8	590
32 1/2	446	38 1/2	530	44 1/2	591
32 5/8	448	38 5/8	531	44 5/8	592
32 3/4	450	38 3/4	533	44 3/4	593
32 7/8	452	38 7/8	534	44 7/8	593
33	453	39	536	45	594
33 1/8	455	39 1/8	538	45 1/8	595
33 1/4	457	39 1/4	539	45 1/4	596
33 3/8	459	39 3/8	541	45 3/8	597
33 1/2	461	39 1/2	542	45 1/2	597
33 5/8	463	39 5/8	543	45 5/8	598
33 3/4	465	39 3/4	545	45 3/4	599
33 7/8	467	39 7/8	546	45 7/8	600
34	468	40	548	46	600
34 1/8	470	40 1/8	549	46 1/8	601
34 1/4	472	40 1/4	551	46 1/4	602
34 3/8	474	40 3/8	552	46 3/8	602
34 1/2	476	40 1/2	553	46 1/2	603
34 5/8	477	40 5/8	555	46 5/8	603
34 3/4	479	40 3/4	556	46 3/4	604
34 7/8	481	40 7/8	558	46 7/8	604
35	483	41	559	47	605
35 1/8	485	41 1/8	560	47 1/8	605
35 1/4	486	41 1/4	562	47 1/4	605
35 3/8	488	41 3/8	563	47 3/8	606
35 1/2	490	41 1/2	564	47 1/2	606
35 5/8	492	41 5/8	565	47 5/8	606
35 3/4	493	41 3/4	567		
35 7/8	495	41 7/8	568		
36	497	42	569		



**CONTAINMENT**  
SOLUTIONS®

### HOW TO PROPERLY GAUGE YOUR TANK:

Underground storage tanks require periodic measurement to determine current inventory level. Using the proper methods when gauging your tank's contents will insure the most accurate reading and insure that you do not damage your tank. The following procedure should be followed whenever you use a gauge stick to determine the amount of product that is in your tank:

- 1) Use a wood dipstick with a rubber or nylon tip. Metallic dipsticks are not recommended. This will insure that frequent tank gaugings or an accidental dropping of the gauge stick into the tank will not damage the tank bottom.
- 2) Slowly lower your gauge stick into the fill port until it touches the tank bottom. Never free drop the gauge stick. This can result in inaccurate measurements due to product splashing. Free dropping can also result in gauge stick damage and tank damage.
- 3) Remove your dipstick slowly and read the product level directly from the gauge stick.

### Water Paste Detection

To detect water in the tank bottom, water detection paste is available from petroleum equipment distributors. However, some water detection paste cannot detect antifreeze mixtures. If antifreeze mixtures are used for the cavity monitoring fluid, the following product is capable of detecting water or antifreeze (brine or up to 50 percent glycol) solution in the tank water bottoms:

WATER FINDER #7686-1870  
DAYCO/NATIONAL  
DAYTON, OH  
TEL: 1-800-283-2926  
FAX: 1-800-688-4854

### Caution

Pressurized deliveries are not recommended. If the delivery vehicle uses pumps to fill the tank, install overfill shutoff equipment in the tank and truck to prevent the tank from being overfilled. **Overfilling the tank under pressure will damage the tank even if the tank vent is unrestricted.**

Containment Solutions, Inc.  
333 North Rivershire Dr., Suite 190  
Conroe, TX 77304  
Tel: 936-756-7731  
Fax: 936-756-7766

**Note:** Calibration chart is based on the fluid level above a 5/16" deflector plate.